

Processor Gateway User Manual

PG11-510

**Implementation
Processor Gateway**

***Processor Gateway
User Manual***

**PG11-510
Release 500
8/95**

Copyright, Trademarks, and Notices

Printed in U.S.A. — © Copyright 1995 by Honeywell Inc.

Revision 01 – August 1, 1995

While this information is presented in good faith and believed to be accurate, Honeywell disclaims the implied warranties of merchantability and fitness for a particular purpose and makes no express warranties except as may be stated in its written agreement with and for its customer.

In no event is Honeywell liable to anyone for any indirect, special or consequential damages. The information and specifications in this document are subject to change without notice.

About This Publication

This publication provides information on the preparation of a Processor Gateway (PG) to participate as a node on a TDC 3000^X Local Control Network. It shows how to set up scheduled data acquisition and parameter value storage between a 45000 computer and points in other LCN nodes. It also explains the writing, installation, testing, and modification of Application Programs (ACPs) in the 45000 that will exchange data with various LCN nodes.

This manual does not, by itself, cover everything you need to know to implement advanced control schemes using the PG. Essential topics covered elsewhere include

- TDC 3000^X System Concepts
- TDC 3000^X System Configuration
- 45000/PMC/PMX Concepts and Use
- Fortran and PAL Programming Languages

A list of related publications is in paragraph 1.3 of this publication.

This manual supports LCN software Release 500.

Change bars are used to indicate paragraphs, tables, or illustrations containing changes that have been made by Document Change Notices or an update. Pages revised only to correct minor typographical errors contain no change bars. All changes made by previous Document Change Notices have been incorporated in this update.

Table of Contents

1 INTRODUCTION

- 1.1 Processor Gateway Role in TDC 3000^X Systems
- 1.2 Processor Gateway Architecture
- 1.3 References

2 CONCEPTS AND MECHANISMS

- 2.1 TDC 3000^X Data Access
 - 2.1.1 Role of Data Definition Tables
 - 2.1.2 Role of CG-Resident Data Points
- 2.2 Scheduled Point Processing
- 2.3 Programmed Point Processing
 - 2.3.1 ACP Installation Modes
 - 2.3.2 ACP Scheduling by the CG
 - 2.3.3 Operator Interfaces to ACP
 - 2.3.4 ACP Execution Example
- 2.4 Processor Gateway Support Functions
- 2.5 Implementation Steps
 - 2.5.1 Configuring the CG
 - 2.5.2 Preparing CG-Resident Data Points
 - 2.5.3 Preparing Data Definition Tables
 - 2.5.4 Compiling ACP
 - 2.5.5 Installing ACP

3 USER PROGRAM INTERFACES

- 3.1 Introduction to User Interface Routines
 - 3.1.1 Common Characteristics
 - 3.1.2 Data Formats
 - 3.1.3 Compatibility of ACP with its DDTs
 - 3.1.4 Commonly Encountered Problems
 - 3.1.5 Error Detection by Interface Calls
- 3.2 Data Transfers
 - 3.2.1 Get Data Interface
 - 3.2.2 Store Data Interface
- 3.3 Text Message Transfers
 - 3.3.1 Get Message Interface
 - 3.3.2 Send Message Interface
- 3.4 ACP Execution Support
 - 3.4.1 Get ACP Status Interface
 - 3.4.2 ACP Termination Interface

4 USING THE PG TABLE BUILDER

- 4.1 Table Builder Overview
 - 4.1.1 Named DDTs
 - 4.1.2 Scheduled DDTs
- 4.2 DDT Template Types
 - 4.2.1 Definitions of Template Value Entries
- 4.3 Input Table Templates

Table of Contents

- 4.3.1 Input-Real
- 4.3.2 Input-Integer
- 4.3.3 Input-ASCII
- 4.3.4 Input-Enumeration
- 4.3.5 Input-Ordinal
- 4.4 Output Table Templates
 - 4.4.1 Output-Real
 - 4.4.2 Output-Integer
 - 4.4.3 Output-ASCII
 - 4.4.4 Output-Enumeration
 - 4.4.5 Output-Ordinal
- 4.5 Other Template Types
 - 4.5.1 Enumeration Set Definition Template
 - 4.5.2 Define a DDT Name Template
 - 4.5.3 Install an ACP Template
 - 4.5.4 Deletions Template
 - 4.5.5 Lists Template
- 4.6 Table Builder Use Steps

5 CG POINT PREPARATION

- 5.1 CG Point Building Overview
- 5.2 Custom Data Segment Construction
 - 5.2.1 Custom Data Segment Heading
 - 5.2.2 Custom Data Segment Parameters
 - 5.2.3 Custom Data Segment Example
 - 5.2.4 Custom Data Segment Compilation Recommendation
- 5.3 ACIDP/CRDP Point Building
 - 5.3.1 ACIDP Scheduling Recommendations
- 5.4 Viewing and Changing ACIDPS & CRDPS
 - 5.4.1 CG Parameter Descriptions

6 SYSTEM STARTUP

- 6.1 Startup
 - 6.1.1 Preparing the CG
 - 6.1.2 Preparing the 45000
- 6.2 Restart Modes
- 6.3 Data Link Status Information

APPENDIX A—STATUS CODES

APPENDIX B—RUN TIME ERROR MESSAGES

APPENDIX C—CG CAPACITIES SUMMARY

APPENDIX D—ASSIGNMENT OF PROCESS UNITS TO CG

INDEX

INTRODUCTION

Section 1

This section discusses the Processor Gateway role in a TDC 3000^X system, reviews the most significant hardware and software components of the PG, and lists the other publications you need to consult during implementation and operation of a PG.

1.1 PROCESSOR GATEWAY ROLE IN TDC 3000 SYSTEMS

Through its data link connection to the Computer Gateway, a 45000 computer has access to a TDC 3000^X control system, enabling it to exchange information with nodes on the Local Control Network.

1.2 PROCESSOR GATEWAY ARCHITECTURE

The Processor Gateway (PG) consists of a software package and data link hardware that is added to a 45000 computer, plus a Computer Gateway (CG), that is joined to the 45000 by a TSDL data link. See Figure 1-1 for an overview of the Processor Gateway hardware and software components.

The 45000 computer's base software includes either PMC or PMX. The PG software extensions to PMC/PMX handle the details of communication between the 45000 and other LCN nodes. Scheduled gathering or export of data values is controlled by user-generated data tables. Provision is also made for user-written control programs to get or give LCN data.

The Computer Gateway is a standard LCN node, housed in a 5-slot TDC 3000^X chassis. Its hardware components include an LCN interface board, an MCP, memory, a power supply, a communication interface board, and a TSDL data link to the 45000. Its memory contains the standard TDC 3000 node-environment software along with CG-specific application software and a user-defined database.

The CG database includes two data point types (ACIDP and CRDP) that are used for controlling the scheduling of special application programs (called ACPs) in the 45000 and for holding data to be exchanged between the 45000 and other nodes on the TDC 3000^X Local Control Network.




Figure 1-1 — Processor Gateway Hardware and Software Structure

6682

1.3 REFERENCES

The following TDC 3000^X publications contain additional information required to understand functions of the Processor Gateway.

Title	Publication No.	Binder
Network Form Instructions	SW12-505	Implementation/Startup & Reconfiguration - 1
System Control Functions	SW09-501	Implementation/Startup & Reconfiguration - 2
Computer Gateway Forms	CG88-500	Implementation/Configuration Forms
Computer Gateway Form Instructions	CG12-500	Implementation/Processor Gateway
Computer Gateway Parameter Reference Dictionary	CG09-540	Implementation/Processor Gateway
Data Entity Builder Manual	SW11-511	Implementation/Engineering Operations - 1
Picture Editor Reference Manual	SW09-550	Implementation/Engineering Operations - 2
Hiway Gateway Parameter Reference Dictionary	HG09-540	Implementation/Hiway Gateway - 1
Hiway Gateway Control Functions	HG09-501	Implementation/Hiway Gateway - 1
Control Language/Application Module Reference Manual	AM27-510	Implementation/Application Module - 2
Application Module Parameter Reference Dictionary	AM09-540	Implementation/Application Module - 1
Control Language/Application Module Data Entry	AM11-585	Implementation/Application Module - 2

45000/PMC/PMX Publications

Title	Section No.	Binder
S/T General Information	25-366	TDC-639
S/T Implementation	25-375	TDC-640
TOTAL Programming/1	25-376	TDC-641
TOTAL Programming/2	25-377	TDC-641
PMX III Implementation/1	25-780	TDC-730
PMX III Implementation/2	25-781	TDC-731
PMX III Configuration	25-782	TDC-731
FREETIME IV	25-346	TDC-622
FILES IV	25-347	TDC-622
FORTTRAN IV	25-348	TDC-622
RTMOS (R170)	25-344	TDC-621

CONCEPTS AND MECHANISMS

Section 2

This section introduces you to the software features that have been added to PMC/PMX that provides a simple, efficient interface to data in other devices on the TDC 3000^X Local Control Network. It concludes with an overview of the steps required to install and test a program.

The primary use of the Processor Gateway is to enable the 45000 PMC/PMX system to accomplish scheduled gathering of data from and the output of data to the LCN (through the CG). Automatic processing of point data is specified by the user through preparation of data tables that reside in the 45000. Additionally, the user can create application programs that also access data on the LCN.

2.1 TDC 3000^X DATA ACCESS

Because the TDC 3000^X is a distributed system, its data is scattered among the various LCN nodes. Each piece of data is assigned to a data owner (program) in the node where it resides. Data can be addressed by the `point_name.parameter` character string (referred to as its "external address") in a request broadcast to all nodes on the LCN. The data owner responds with a numeric "internal address" that can be used for direct access to the data. If it is necessary to access data on a remote LCN connected through a Network Gateway, the point must be addressed as `id\point_name.parameter`, where `id` is the remote system identifier.

If the 45000 always requested a piece of data by its "external address" the "internal address" would need to be obtained each time. Time during LCN loading is saved by having the 45000 obtain the "internal address" once, then save it each time the data is requested. This is automatically done during the creation of special tables known as Data Definition Tables (DDT) used for both scheduled and programmed point processing.

Current process values can be obtained from the CG, the Applications Module, or the Hiway Gateway (data from Data Hiway boxes).

2.1.1 Role of Data Definition Tables

There are two types of Data Definition Tables: "named" DDTs provide an interface between Application Programs and the TDC 3000^X data points. "Scheduled" DDTs are used to provide a direct interface between 45000 points and TDC 3000^X data points, and are not related to user-created programs.

Each Data Definition Table (DDT) specifies a set of data point parameter values to be accessed and also indicates how each value is to be processed. (When parameter arrays are accessed, individual elements of the array are specified separately.) To access LCN data, a 45000 program specifies which DDT is to be used and receives or provides arrays of point parameter values.

Each named DDT contains only input points or output points; within each table the points are grouped by data type (real, integer, ASCII, and enumeration). Individual point and parameter names are specified along with individual point-value processing information.

The DDT is not part of a program; it is separately constructed and installed.

2.1.2 Role of CG-Resident Data Points

There are two types of CG-resident data points that can be associated with a program in the 45000.

- The Advanced Control Interface Data Point (ACIDP) has the multiple duties of ACP execution control, of being a message buffer, and of providing Custom Data Segments for storage of calculated values from the 45000 or other LCN nodes.
- The Calculated Results Data Point (CRDP) role is restricted to that of storage for calculated values.

An ACP can have one ACIDP connection. If its ACIDP's Access Key value (established when configured) permits, an ACP can write to any CG or Application Module data point unless that point's access is limited to the Entity Builder.

2.2 SCHEDULED POINT PROCESSING

Automatic cyclic exchange of data between 45000 points and TDC 3000^X data points is controlled by the contents of "scheduled" DDTs. These DDTs are used by an internal ACP named PGDCP.

To establish scheduled point processing you connect PGDCP to an ACIDP of your choice in each CG (see paragraph 6.1.1.1) and add points to the "scheduled" DDTs (one exists for each of two base-scanning frequencies) For each point to be accessed, you need to define the following:

- Point and parameter names of the LCN data point
- Point record name and parameter name of the associated 45000 point
- Schedule frequency, rate, and phase
- Value processing such as input limit checks.

Details of DDT preparation are found in Section 4.

2.3 PROGRAMMED POINT PROCESSING

A user application program that communicates with other LCN nodes is referred to as an Advanced Control Program (ACP). It executes as a FREETIME IV program and uses special interface subroutines that simplify the tasks required in the exchange of data with other TDC 3000^X nodes and boxes. These interface subroutines can be called from either Fortran or PAL. Specifics of the subroutine calls are found in Section 3, "User Interface Subroutines," but a brief outline of their use is as follows.

Execution of ACPs can be divided into three stages, each with its related interface routines:

Setup stage—The "Get ACP Status" subroutine (GETSTS) obtains information that indicates why the ACP has been activated, thereby establishing what actions may be necessary at this specific activation.

Run stage—Subroutines for exchange of data with LCN-resident modules are used to

- Get LCN data (GETDTA)
- Store LCN data (STRDTA)
- Receive LCN messages (GETMSG)
- Send LCN messages (SNDMSG)

Cleanup stage—The "Termination" interface subroutine (PRGTRM) provides for both normal and abnormal program termination, and normally is the last executing statement of an ACP.

NOTE

Other nodes on the LCN cannot directly access data in the 45000. Other nodes can, however, read data stored by ACPs in the CG's ACIDP and CRDP data points.

The definition of what LCN point parameters are to be accessed is contained in "Named" DDTs that are referenced in the GETDTA and STRDTA calls. Details on the creation of Named DDTs is found in Section 4 of this manual.

An ACP can send character-string messages to all operator stations within its operating area by using the SNDMSG interface subroutine. An option to wait for operator confirmation is provided.

Other devices on the LCN can send character-string messages to an ACP through its connected ACIDP. Messages are held by the CG pending an ACP call of the GETMSG interface routine. Presence of a pending message at the CG is detected for the ACP by the GETSTS interface subroutine.

2.3.1 ACP Installation Modes

ACP scheduling and capabilities are affected by its manner of installation. Those ACPs that are "connected" to an ACIDP are normally scheduled by the CG and use all six interface subroutines. Those ACPs that are not ACIDP-connected are scheduled by the 45000 and can use only the Get Data interface.

Tables 2-1 and 2-2 depict the limitations on ACPs as determined by your installation choices.

Table 2-1—ACP Scheduling Capabilities

	ACP is not connected to an ACIDP	ACP is connected to an ACIDP
ACP can be initiated by		
- CG - Cyclic	no	yes
- CG - Periodic	no	yes
- Operator Demand	no	yes
- Process Special	no	yes
- Message waiting at CG	no	yes
- 45000	yes	yes*
*Can use only the Get Data interface.		

Table 2-2—Interface Subroutines Effective

	ACP is not connected to an ACIDP	ACP is connected to an ACIDP
- Get Data	yes**	yes**
- Store Data	no	yes
- Get Message	no	yes
- Send Message	no	yes
- Get ACP Status	no	yes
- ACP Termination	no	yes
**Test values are substituted for live input data when specified in the referenced Data Definition Table.		

2.3.2 ACP Scheduling by the CG

NOTE

Because the INH_STAT parameter is initially set to the "inhibit" state, first-time CG scheduling of an ACP cannot begin until after operator action "permits" operation through the ACIDP's Detail Display or a custom display allows access to that parameter. See the *CG Parameter Reference Dictionary* for details.

2.3.2.1 Program Activation

There are five choices for normal-mode scheduling of ACPs by the CG: cyclic, periodic, demand, cyclic/demand, and periodic/demand.

Periodic and Cyclic Scheduling

Periodic programs first run at a specified daily start time (STIME) and thereafter run at a specified time interval (RTPERIOD). The STIME value must be less than RTPERIOD.

Example 1: RTPERIOD = 24:00:00 STIME = 17:00:00

This program runs each day at 17:00:00 hours.

Example 2: RTPERIOD = 08:00:00 STIME = 07:00:00

This program runs each day at the following times: 07:00:00, 15:00:00 and 23:00:00.

Cyclic programs run at a specified time interval (RTPERIOD).

Example 3: RTPERIOD = 00:10:00

This program runs every 10 minutes.

A Periodic or Cyclic program runs immediately upon a CG initialization event (see subsection 5.4.1) if in Normal Mode and its ACIDP was built with RUN_INIT = ON. If RUN_INIT = OFF, a Cyclic program first runs at RTPERIOD seconds following the initialization event and a Periodic program first runs at the time of day specified by STIME.

The time-interval range for both periodic and cyclic programs is 10 seconds to 24 hours. The subcategories of periodic/demand and cyclic/demand programs also allow for activation by process-operator demand from the Universal Station.

Operator Demand

An ACP can be activated from a Universal Station through the PROCESS target on its ACIDP's detail display if its activation type is demand, cyclic/demand, or periodic/demand. You can also create custom displays that provide for the activation of ACPs (by setting the OPER_DMD parameter of the ACIDP to ON). See the *Picture Editor Reference Manual* in the *Implementation/Engineering Operations - 2* binder for custom display-building details.

Operator demand is also used in the recovery of an ACP from the Abort state. See OPER_DMD in the *CG Parameter Reference Dictionary* in the *Implementation/Computer Gateway* binder, for details.

PPS Activation

A connected ACP is immediately activated following a store data of ON to its ACIDP's PPS parameter from another ACP, an HG (Event Initiated Processing), or an AM (CL "Initiate" statement). This activation method is also used by the CG upon receipt of a Message to an ACP. Process special event-activation is independent of scheduling type.

2.3.2.2 Program Termination

The PRGTRM interface routine is used to inform the CG that the ACP has gone from "Run" to "Off/Delay" state or to "Abort" state. Once in "Abort" state, the CG suspends periodic or cyclic scheduling of the ACP. Reactivation of the ACP requires operator demand or a 45000 restart.

A program abort alarm is sent to the LCN's Real Time Journal by the CG whenever an ACP terminates in "Abort" state.

For those instances when you need the 45000 to control an ACP's execution, and also need the ACP full input and output capabilities, attach the ACP to an ACIDP without the Program Termination interface. Therefore, after the first activation, the CG treats the ACP as busy and ignores any scheduling events.

2.3.2.3 Program Inhibit

The process operator can inhibit or permit an ACP's activation by the CG by selecting the INH_STAT target on the associated ACIDP's Universal Station Detail Display. Optionally, the operator can construct a custom display that performs this function by a store of INHIBIT/PERMIT to the ACIDP's INH_STAT parameter. If the ACP is already in the "Run" state when the inhibit request is received, any outputs are blocked at the CG.

2.3.3 Operator Interfaces to ACP

Different types of operator access to operation of the ACP are provided at the TDC 3000^X Universal Station (process operator) and at the 45000 programmer's terminal (computer operator).

2.3.3.1 Process Operator Interfaces

The process operator can affect ACP operation from the Universal Station only when that ACP is connected to an ACIDP.

The process operator can view ACP status, inhibit ACP operation, demand immediate ACP execution (if permitted for that ACP), view ACIDP and CRDP point parameter values, and view or change ACIDP and CRDP Custom Data Segment values. The operator's ability to change Custom Data Segment values is controlled by access restrictions established at point building time.

ACP-initiated screen messages can specify operator confirmation.

2.3.3.2 Computer Operator Interfaces

From a 45000 terminal, you communicate with an ACP as with any other FREETIME IV program; by using PGBLD, you can view ACP status and make or break its ACIDP connection.

2.3.4 ACP Execution Example

The following is a simplified example of ACP execution. It is based on assumptions of ACIDP connection and demand scheduling. See Figure 1-1 for an illustration showing relationships of the referenced software functions.

At a Universal Station

1. The ACP is demanded through its ACIDP's Detail Display

In the CG

2. The CG Scheduler program creates and sends a message requesting a turn on of the ACP.

In the 45000

3. The PG Data Communicator Program (PGDCP) activates the ACP.
4. The ACP does initial housekeeping (GETSTS).
5. The ACP calls GETDTA.
6. The ACP is suspended. PGDCP creates a message based on the DDT referenced and sends it to the CG.

In the CG

7. The CG routes the message to the Data Owner (via the LCN Communication Handler if elsewhere on the LCN).
8. When the return message is available from the Data Owner, the CG sends it to the 45000.

In the 45000

9. The interface routine writes the retrieved information into storage allocated by the ACP and PGDCP "wakes up" the suspended ACP.

Steps 5-9 are repeated for additional interface routine calls.

10. The ACP acts on the data, then goes into its cleanup stage (PRGTRM).

2.4 PROCESSOR GATEWAY SUPPORT FUNCTIONS

There are three major entities that provide LCN data access support in the 45000:

- User Interface Subroutines
- The PG Table Builder Program (PGBLD)
- The Data Communicator Program (PGDCP)

The User Interface Subroutines are listed below along with paragraph number references to where detailed information is found in this manual.

Paragraph	Interface Description	Name
3.2	Data Transfers	
3.2.1	Get Data	GETDTA
3.2.2	Store Data	STRDTA
3.3	Text Message Transfers	
3.3.1	Get Message	GETMSG
3.3.2	Send Message	SNDMSG
3.4	ACP Execution Support	
3.4.1	Get ACP Status	GETSTS
3.4.2	ACP Termination	PRGTRM

The PG Table Builder Program is used to:

- Create Data Definition Tables from templates
- Connect/disconnect ACPs to ACIDPs
- List Directory Entries
- Delete Directory Entries

The Data Communicator Program is used to:

- Control the execution of scheduled DDTs
- Perform required value processing
- Handle all 45000-LCN data conversions
- Communicate with the CG over the data link
- Issues Run-Time Error Messages (Appendix B)

2.5 IMPLEMENTATION STEPS

The exact sequence varies depending on specific circumstances, but all the following steps are necessary to complete the installation of an ACP. Number references included in the following headings point to later sections in this manual where more detailed information is found.

CAUTION

Be sure to initiate a checkpoint of the CG any time its database is modified by the addition or deletion of points, by ACP connect or disconnect, etc.; otherwise, the CG database reverts to the previous contents during its next restart.

2.5.1 Configuring the CG

At the TDC 3000^X Universal Station, modify the system NCF to include the CG. Refer to the *System Configuration Guide* as a starting point if this procedure is unfamiliar. As part of LCN Nodes Configuration, assign one or more Process Units to the CG (see *Network Form Instructions* and Appendix D of this manual for additional information).

With software before Rel 200, the number of data links (1) and baud rate (76800) are selected during node configuration. Starting with Rel 200, however, those parameters and some additional CG configuration entries are made through the CG CONFIGURATION display (entered from the CM BUILD AND CONFIGURATION menu). Use the default values for all entries except "Number of Links" which must be changed to 1 Link. See the *CG Parameter Reference Dictionary* for definitions of the configuration entries and for the normal default values.

On completion of R200 CG configuration (or configuration change), you must demand-checkpoint the CG, then shut down and restart the node in order for the changes to take effect.

2.5.2 Preparing CG-Resident Data Points (5)

At a TDC 3000^X Universal Station, use the CL compiler to define any Custom Data Segments, then build the ACIDP and CRDP points. Installed ACIDP and CRDP parameter values can be displayed at a Universal Station (Point Detail Display).

2.5.3 Preparing Data Definition Tables (4)

At the 45000 terminal, build the Data Definition Tables using PGBLD. Any referenced points must be built and be accessible through the data owner before the table build can be completed. ACP references to nonexistent or incomplete DDTs are rejected by the interface subroutines.

2.5.4 Compiling ACP

At the 45000 terminal, compile the ACP. Each ACP is separately compiled and linked through standard 45000 programs.

2.5.5 Installing ACP (4)

At the 45000 terminal, use PGBLD to install the ACP.

USER-PROGRAM INTERFACES

Section 3

This section discusses each of the program interfaces that provide necessary services that enable PAL or Fortran programs to communicate with other nodes on the TDC 3000^X Local Control Network.

3.1 INTRODUCTION TO USER INTERFACE ROUTINES

The immediately following paragraphs cover information that relates to general characteristics of user-interface calls.

Beginning at subsection 3.2, details on each of the interface calls are given. Each call is shown as it would appear in a Fortran program.

3.1.1 Common Characteristics

- The Get Data and Store Data routines returns status information, both on the call itself and for each accessed point or array.
- All arrays are of a single dimension.
- Each call to one of these interfaces must include all defined parameters in the order shown. All parameters are passed by reference (location), not by value.
- To use the Get Data or Store Data interfaces, you must specify the data type assigned to each data point parameter being accessed. If state values are used, you also need to prepare tables of enumeration values associated with predefined parameter types and your custom data segments. In the 45000, state values for enumerations are expressed as integer pointers to these enumeration set tables.

For information on enumeration sets assigned to the predefined parameter types, see the *Application Module, Hiway Gateway, and Computer Gateway Parameter Reference Dictionaries*.

3.1.2 Data Formats

Data conversions that may be required because of differences between the 45000 and LCN data formats are performed by PGDCP. The following conventions must be observed in the 45000 to ensure data compatibility.

Reals—24-bit 45000 floating point

Integer—Maximum value range is -32767 to 32767

Ascii—24-byte character string

Enumeration—Integer values as assigned through enumeration set definition tables
(see subsection 4.5.1)

Ordinal—Integer values representing the defined ordinal position (0-n) of enumeration values.

3.1.3 Compatibility of ACP with Its DDTs

Because each ACP and its Data Definition Table(s) are built separately, the system cannot enforce compatibility between an ACP and its DDT(s). That responsibility is up to you.

In particular, it is vital that the dimensions set for data-receiving arrays be large enough to accommodate the maximum data amounts permitted by the named DDT.

Specific points to remember for Get Data and Store Data are:

- Dimensions set for each array must be equal to or greater than the point count in the referenced DDT. If the program arrays are too small, data or code may be corrupted (Get Data) or inappropriate data may be exported (Store Data).
- The dimension values for status table arrays must be equal-to or greater-than the total number of points of all types in the referenced DDT because this array is to receive a status code for each returned value, positioned according to its location in the DDT.

3.1.4 Commonly Encountered Problems

- Failure to specify array sizes that match DDT sizes.
- Failure to use the PRGTRM call as the last statement in an ACP (unless subsequent activation is to be by the 45000, not the CG).

3.1.5 Error Detection by Interface Calls

The interface calls detect two types of errors and return information on them to the ACP through call parameter values.

The RETURN_STATUS parameter shows whether the request was processed successfully, and if not, what error type was involved. Some typical errors flagged by the return status are:

- LCN access problems or data link failure
- ACP installation or mode problems
- Data problems in the call or with a referenced DDT
- Call rules violations

The STATUS_TABLE parameter points to an array containing a data status code for each point parameter accessed. These status codes show whether there have been any data access errors that would invalidate a requested get or store operation for that point parameter. There are over 200 different data access error codes that can be returned as described in Appendix A.

Data transfer calls employ both RETURN_STATUS and STATUS_TABLE PARAMETERS, while text message transfers use only RETURN_STATUS. See the individual calls for more information.

Violations of RTMOS/Files IV rules result in the ACP being aborted, and an error message is logged at the 45000 console terminal. See the RTMOS user documentation for message interpretation.

3.2 DATA TRANSFERS

The interface routines in this group require the use of Data Definition Tables (DDT) that specify which points are to be accessed and what pre/post processing is to be done on data values. See Section 4 for DDT preparation and installation details.

Individual elements of parameter arrays (but not whole arrays) can be specified in the DDT.

3.2.1 Get Data Interface

This routine fetches data from the CG or elsewhere on the LCN. The specification of which data is to be fetched is contained in the Data Definition Table referenced by the call. Any errors encountered during execution of the routine as well as individual point data errors are returned to the calling program.

3.2.1.1 Fortran Subroutine Call for Get Data

```
CALL GETDTA    (DATA_TABLE_NAME, REAL_VALUES_ARRAY, INTEGER_VALUES_ARRAY,
                ASCII_VALUES_ARRAY, ENUM_ARRAY, STATUS_TABLE,
                RETURN_STATUS)
```

3.2.1.2 Parameter Definitions for Get Data

DATA_TABLE_NAME—The name of a packed array of ASCII characters that contains the name of the input Data Definition Table to be used. The table name is a maximum of eight characters long.

REAL_VALUES_ARRAY—The name of a single-dimension array into which the fetched Real values are to be stored. Bad values are returned as NaN (-0).

INTEGER_VALUES_ARRAY—The name of a single-dimension Integer array into which the fetched Integer values are to be stored. Bad values are returned as NaN (-0).

ASCII_VALUES_ARRAY—The name of a packed array into which fetched ASCII strings are to be stored. Bad values are returned as strings of 24 question marks.

ENUM_ARRAY—The name of a single-dimension Integer array into which fetched Enumeration or Ordinal values are to be stored.

STATUS_TABLE—The name of a single-dimension Integer array for the storage of point-related error/status information. A status code is returned for each requested value. See Appendix A for a listing of Data Access error/status codes.

RETURN_STATUS—The name of an Integer variable where the request completion status is to be stored. The assigned meanings are:

- 0 – Normal return. Request successfully completed.
- 1 – Referenced DDT does not exist
- 3 – Unable to access the CG
- 4 – Wrong execution state
- 5 – Request completed, but errors exist in data
- 10 – Get-table empty
- 16 – Specified ACIDP not found

3.2.2 Store Data Interface

This routine sends data to points in the CG or elsewhere on the LCN. The specification of what points are to receive data is contained in the Data Definition Table referenced by the call. Errors encountered during execution of the routine, as well as individual point data errors, are returned to the calling program.

To use this call, the ACP must be connected to an ACIDP with read/write access. See the *System Control Functions Manual* for other write access restrictions.

3.2.2.1 Fortran Subroutine Call for Store Data

```
CALL STRDTA (DATA_TABLE_NAME, REAL_VALUES_ARRAY, INTEGER_VALUES_ARRAY,
             ASCII_VALUES_ARRAY, ENUM_ARRAY, STATUS_TABLE,
             RETURN_STATUS)
```

3.2.2.2 Parameter Definitions for Store Data

DATA_TABLE_NAME—The name of a packed array of ASCII characters that contains the name of the output Data Definition Table to be used in the "Store Data" operation. The table name is a maximum of eight characters long.

REAL_VALUES_ARRAY—The name of a single-dimension array that contains the Real values to be stored.

INTEGER_VALUES_ARRAY—The name of a single-dimension Integer array that contains the Integer values to be stored.

ASCII_VALUES_ARRAY—The name of a packed array that contains the ASCII strings to be stored.

ENUM_ARRAY—The name of a single-dimension Integer array that contains the Enumeration or Ordinal values to be stored.

STATUS_TABLE—The name of a single-dimension Integer array for the storage of returned point-related error/status information. A status code is returned for each requested store value. See Appendix A for a listing of Data Access error/status codes.

RETURN_STATUS—The name of an Integer variable where the request completion status is to be stored. The assigned meanings are:

- 0 – Normal return. Request was successfully completed.
- 1 – ACP Reference not found
- 3 – Unable to access the CG
- 4 – Wrong execution state
- 5 – Request completed, but errors exist in data
- 6 – Specified ACIDP not found or ACP not connected to an ACIDP
- 9 – Access key incorrect
- 15 – ACIDP not in RUN state

3.3 TEXT MESSAGE TRANSFERS

The two interface routines in this group are used to send and receive character string messages over the LCN.

3.3.1 Get Message Interface

This routine is used to fetch a character-string message held in a CG buffer for this program's ACIDP. The message presence is determined as the result of a Get ACP Status request.

3.3.1.1 Fortran Subroutine Call for Get Message

```
CALL GETMSG (TEXT_ARRAY, TEXT_ARRAY_SIZE, RETURN_STATUS)
```

3.3.1.2 Parameter Definitions for Get Message

TEXT_ARRAY—The name of a packed array of characters where the message is to be stored (must provide for up to 120 ASCII characters).

TEXT_ARRAY_SIZE—The name of an Integer variable that specifies the maximum number of characters expected (120-character limit).

RETURN_STATUS—The name of an Integer variable where the request-completion status code is to be stored. The assigned meanings are:

- 0 – Normal return. Request was successfully completed.
- 1 – Request completed, but trailing characters in excess of specified Text_Array_Size have been deleted.
- 2 – No message was pending.
- 3 – Not defined.
- 4 – Request was successfully completed. A second message is now queued at the ACIDP.
- 5 – Request completed with trailing characters deleted. A second message is now queued at the ACIDP.
- 6 – Valid ACIDP not found.
- 15 – ACIDP not in correct execution state.

3.3.2 Send Message Interface

This routine is used to send a message to all operator stations assigned to the same unit as this program's ACIDP. A request to wait for operator confirmation is optional. If operator confirmation is requested, execution of the requesting program is suspended until either the confirmation occurs or until its specified wait-time expires. The requesting program receives an indication of whether confirmation or a time out occurs.

3.3.2.1 Fortran Subroutine Call for Send Message

```
CALL SNDMSG (TEXT_ARRAY, MESSAGE_SIZE, CONFIRM, WAIT_TIME,
             DESTINATION, RETURN_STATUS)
```

3.3.2.2 Parameter Definitions for Send Message

TEXT_ARRAY—The name of a packed array of characters that contains the message to be sent.

MESSAGE_SIZE—The name of an Integer variable that specifies the number of characters to be transmitted. The maximum number of characters depends on message destination: 60 for CRT displays, 72 for printing, and 120 for HM archiving. Messages over the maximum number of characters are truncated. All messages are archived.

CONFIRM—The name of a logical variable that when TRUE (integer 0) specifies that a message confirmation is requested. Note that this parameter is treated as FALSE (integer 1) if the message destination is printer only.

WAIT_TIME—The name of an Integer variable (0 to 3600) that specifies the number of seconds the system is to wait for confirmation before returning control to the requesting program with a no "confirm" return status. (Allow for a built-in time lag of up to 10 seconds.) The Wait Time parameter is ignored if the Confirm parameter is set to OFF or the message destination is printer only.

DESTINATION—The name of an Integer variable that specifies where the message is to be sent, as follows:

- 0 – CRT only
- 1 – Printer only
- 2 – Both

RETURN_STATUS—The name of an Integer variable where the request-completion status is to be stored. The assigned meanings are:

- 0 – Normal return. Request was successfully completed (and, if requested, confirmed).
- 2 – Message could not be sent.
- 3 – Unable to access the CG.
- 4 – Message was sent, but wait time elapsed with no confirmation.
- 6 – Valid ACIDP not found.
- 15 – ACIDP not in correct execution state.

3.4 ACP EXECUTION SUPPORT

These interface routines affect the orderly execution and termination of an ACP.

3.4.1 Get ACP Status Interface

This routine fetches a value that enables the requesting program to determine why the system has turned it on.

3.4.1.1 Fortran Subroutine Call for Get ACP Status

```
CALL GETSTS    (ACT_STAT)
```

3.4.1.2 Parameter Definitions for Get ACP Status

ACT_STAT—The name of an Integer variable (1-7) that receives the activation reason, as follows:

- 1 – Initialization event
- 2 – Message waiting
- 3 – Operator demand
- 4 – Process Special
- 5 – Scheduled turn on (periodic or cyclic)
- 6 – Not used
- 7 – Initiated by 45000

3.4.2 ACP TERMINATION INTERFACE

This routine terminates the execution of the calling ACP. It normally is the last operating statement if the ACP is attached to an ACIDP (see subsection 2.3.2.2 for the exception). A termination status code is stored in the associated ACIDP's ABORTCOD parameter. If an ACP is aborted by the operating system, a system-assigned abort code is stored.

The termination code assigned by this call can be viewed at a Universal Station (see the definitions for ABORTCOD and EXECSTAT in subsection 5.4.1) but in a revised form. The integer value assigned here is translated into four hexadecimal digits (0000 to 00FF). Thus, an ACP-assigned abnormal termination code of 15 appears at the Universal Station display as 000F.

The execution state of an ACIDP can be changed from ABORT to normal by operator demand through a Universal Station. See OPER_DMD in the *Computer Gateway Parameter Reference Dictionary* for additional details.

3.4.2.1 Fortran Subroutine Call for ACP Termination

```
CALL PRGTRM    (TERMINATE_CODE)
```

3.4.2.2 Parameter Definitions for ACP Termination

TERMINATE_CODE—The name of a variable of type Integer that must contain zero or a positive value (1 to 255). Zero value indicates normal termination. Nonzero values are user-specified codes for non-normal termination (abort).

USING THE PG TABLE BUILDER

Section 4

This section explains how you prepare the special tables that are used in getting or storing data for PG functions.

4.1 TABLE BUILDER OVERVIEW

The PG Table Builder (PGBLD) is used to build the Scheduled and Named Data Definition Tables used to control the exchange of data between the 45000 and LCN nodes. It also provides for enumeration set definition and table maintenance functions (list and delete). Additionally, the Table Builder is used to connect and disconnect ACPs to ACIDPs.

The steps are:

1. Copy or add one or more images of one or more types of predefined "templates" from FILES IV files.
2. Edit the templates to include parameter values.
3. Invoke PGBLD to build a table or to take other specified actions.

There are 13 types of templates that are used alone or in combinations.

See subsection 4.6 for more information on these execution steps.

4.1.1 Named DDTs

The templates used to build Named DDTs are:

- | | |
|-----------------------------|---------------------|
| -Define DDT Name (required) | |
| -Real Input | -Real Output |
| -Integer Input | -Integer Output |
| -ASCII Input | -ASCII Output |
| -Enumeration Input | -Enumeration Output |
| -Ordinal Input | -Ordinal Output |

Each Named DDT can contain only input (Get Data) or output (Store Data) parameters. Points within an input or output Data Definition Table can be of more than one data type, but they must be grouped by type and a type group cannot repeat within a DDT. Table 4-1 illustrates characteristics of these table types.

CAUTION

You must not include both Enumeration and Ordinal data types in the same DDT.

Table 4-1 — Named DDT Table Types and Data Types

Table Types	Allowed Data Types	PT Count Max
Input	Real Integer ASCII Enumeration or Ordinal	300
Output	Real Integer ASCII Enumeration or Ordinal	300

4.1.2 Scheduled DDTs

The two Scheduled DDTs (PGCSC1 and PGCSC2) employ most of the same templates as Named DDTs, but there are significant differences in how they are prepared and used.

- You do not specify a table name for Scheduled DDTs, the parameter value SCHEDULE BASE does this.
- You can enter (add) one point or groups of points at a time.
- Points can be randomly entered without consideration of point type, input/output, or Schedule Base assignment.

Details of Scheduled DDT point assignments are found in the template descriptions that follow and in the template comment fields.

The templates used to build Scheduled DDTs are:

- | | |
|--------------------|---------------------|
| -Real Input | -Real Output |
| -Integer Input | -Integer Output |
| -Enumeration Input | -Enumeration Output |
| -Ordinal Input | -Ordinal Output |

4.2 DDT TEMPLATE TYPES

There is one FILES IV file for each template type. The file name contains a mnemonic that identifies its function. For example, the template used to build ReaInput data points is in the file named DDTRI.PGTMPL.MEDIA.

Following is a list of the template names followed by type or function and a paragraph number reference:

DDTRI.PGTMPL.MEDIA	Real Input	4.3.1
DDTRO.PGTMPL.MEDIA	Real Output	4.4.1
DDTIL.PGTMPL.MEDIA	Integer Input	4.3.2
DDTIO.PGTMPL.MEDIA	Integer Output	4.4.2
DDTAI.PGTMPL.MEDIA	ASCII Input	4.3.3
DDTAO.PGTMPL.MEDIA	ASCII Output	4.4.3
DDTEI.PGTMPL.MEDIA	Enumeration Input	4.3.4
DDTEO.PGTMPL.MEDIA	Enumeration Output	4.4.4
DDTOI.PGTMPL.MEDIA	Ordinal Input	4.3.5
DDTOO.PGTMPL.MEDIA	Ordinal Output	4.4.5
DEFES.PGTMPL.MEDIA	Define Enumeration Set	4.5.1
DEFDDT.PGTMPL.MEDIA	Define DDT Name	4.5.2
INSACP.PGTMPL.MEDIA	Install ACP	4.5.3
DELETE.PGTMPL.MEDIA	Delete from Directories	4.5.4
LIST.PGTMPL.MEDIA	List Directory Contents	4.5.5

Templates are in free form, and use the "blank" character to separate fields. Each entry in a template is in the general form "item = value." The "value" field cannot contain embedded blanks after the first nonblank character and must be followed by one or more blanks. The "item" field can use one or more blanks to separate words (e.g., SCHEDULE BASE). Comments are included to help explain template function and are defined by the character "*" (you may add additional comments if you wish). If "*" appears in the first column of a line, the entire line is treated as a comment. Within a line, a comment must both start and end with "*." An example of comment use within a template follows:

```
*1*   SCHEDULE   BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*   POINT RECORD= *A9*      PARAMETER= *A9*   PSP?= N   *Y/N*
```

When building Named DDTs, this line pair is left as a comment (or may be deleted), but when building Scheduled DDTs the "*1*" at the beginning of each line must be removed, and the required parameter data inserted (replaces comment field following "="). The "*I3*" and "*A9*" comment fields indicate the data type and maximum number of characters accepted for value entries. The following conventions are used in the comments to identify value types:

- *F* - Real value
- *In* - Integer value not to exceed "n" decimal digits
- *Ann* - An ASCII string not to exceed "nn" characters
- *text* - Where *text* defines the acceptable "value" set

4.2.1 Definitions of Template Value Entries

The following define the formats and significance of specific value entries to be made to the templates. Template descriptions begin at subsection 4.3.

ACIDP	Name of the ACIDP associated with the ACP. This is a TDC3000 ^X LCN point name and must be from one-to-eight characters long and begin with "A..Z" or "0..9." Characters within the point name must be "A..Z", "0..9" or "_" (underscore). All-numeric names are not permitted. Consecutive underscore characters or trailing underscores are not permitted. The first trailing "blank" character signals end of the point name. An entered "-" (hyphen or minus sign) is interpreted as (and is replaced by) an underscore.
ACP	The Advanced Control Program name, from one to six characters beginning with "A..Z." Characters within the name consist of "A..Z" and "0..9."
ALGOA	This specifies the type of scaling calculation to be performed on the input value (V). The accepted algorithms are: 0 = no calculation 1 = $V+K1$ 2 = $V-K1$ 3 = $V*K1$ 4 = $V\div K1$ 5 = $V*K1+K2$
BV SUBST?	If the input is a BAD VALUE, this option permits a constant to be substituted for it.
CIU	A 45000 can be connected to more than one CIU (CG), and this item defines which CG (1..3) is used to access the data point.
CLAMP LOW? CLAMP HI?	When selected, these options "clamp" the value at the limit if the entered limit is exceeded. If clamping is not selected, values failing limit checks are set to bad.
CONSTANT	When BV SUBST? is selected, this is the substitution value.
DATA TABLE	The DDT name, one to eight characters consisting of "A..Z" and "0..9."

ENUMERATION	The enumeration ASCII value consisting of from one to eight characters.
ENUMERATION SET ID	The name of an enumeration set to be used with the designated point parameter to provide transformation between TDC 3000 ^X and 45000 data bases. From one to eight characters, "A..Z" and "0..9."
K1, K2	Constant values used in the scaling algorithm calculations. Required only if used by the selected algorithm.
LF SUBST?	If the CG data link fails, the input value defaults to -0 unless Y is selected. If Y is selected, the previous value is retained.
LIMIT CK?	Permits the value to be limit checked after any scaling calculations. If this option is selected (Y), a low limit and/or high limit must be entered.
LOW LIMIT HIGH LIMIT	Limit values used with the LIMIT CK? option. Only the limit(s) to be checked need be entered.
ORDINAL	Position (0-n) of an enumeration in an assigned set of values.
PARAMETER	May refer either to a TDC 3000^X LCN or 45000 point parameter, depending on context within the DDT type. TDC 3000^X: One to eight characters, beginning with "A..Z." Characters within the parameter name must be "A..Z", "0-9" or "_" (underscore). All-numeric names are not permitted. Consecutive underscore characters or trailing underscores are not permitted. The first trailing "blank" character signals the end of the parameter name. An entered "-" (hyphen or minus sign) is interpreted as (and is replaced by) an underscore. Example: PV SP OP 45000: One to nine characters consisting of "A..Z", "0-9." The first trailing "blank" character signals end of the parameter name. Example: PV SP

Parameter names of either variety can be subscripted (to allow accessing an individual element of a parameter array) by enclosing the subscript value in parentheses immediately following the parameter name.

Example: XYZ(2)

PHASE

When RATE is greater than SCHEDULE BASE, PHASE specifies an offset in seconds from the SCHEDULE BASE time. Enter the default value ANY to have the builder assign the point to the least full phase. Otherwise, this value must be zero or an exact multiple of the SCHEDULE BASE value.

Example: SCHEDULE BASE = 30
RATE = 120
PHASE = 60

This example schedules an entry in the 30-second DDT tables that are processed every 120 seconds starting 60 seconds into the base processing period.

POINT NAME

Represents a TDC3000^X LCN point name that must be from one to eight characters long and begin with "A..Z", "0..9" or "\$." Characters within the point name must be "A..Z", "0..9" or "_" (underscore). All-numeric names are not permitted. Consecutive underscore characters or trailing underscores are not permitted. The first trailing "blank" character signals end of the point name. An entered "-" (hyphen or minus sign) is interpreted as (and is replaced by) an underscore.

Example: AM5HGDDC
095HGSWT
\$05HGDDC (" \$" designates a system-reserved point name)

POINT RECORD

Represents a 45000 point name that must be from one to nine characters long. Characters in the point record name must be "A..Z" and "0..9."

Example: GGD007
09FT05

PSP?

When set Y, this option forces demand processing (process special) of the 45000 point after the input value is stored to the specified parameter of the point.

RATE	Specifies the actual frequency (in seconds) of processing for that point parameter. This value <u>must</u> be an exact multiple of the SCHEDULE BASE value.
SCHEDULE BASE	Used to identify a scheduled DDT. The SCHEDULE BASE value is one of two DDT Scheduler processing rates (PGCSC1 and PGCS2) configured for your system (see subsection 6.1.2.1). The value entered must match one of these configured rates.
STATUS	This option defines the ACP program execution status. Valid entries are: - N - Normal - T - Test - R - Restricted
STORE?	This option applies only to values of type Real. It establishes whether the value—after scaling calculations—is to be stored to the TDC 3000^X data point. The selections are - G - store only if the value is good (do not store if not good) - B - store whether the value is good or bad - D - do not store the value whether good or bad
TEST VALUE	When USE TEST? is selected, this value is substituted.
USE TEST?	While set Y, a test value is substituted for the input value of a point in a named or scheduled DDT.
VALUE	An integer representing the internal 45000 value assigned to the associated ASCII enumeration value. Enumeration values are fetched from and stored to the TDC 3000 ^X as ASCII values; however, these values are maintained in the 45000 as integer values. This transformation is performed by the input and output processor as defined by the ENUMERATION SET.

4.3 INPUT TABLE TEMPLATES

4.3.1 Input-Real

Used to build a DDT table entry to "fetch" a real value from a TDC 3000^X point parameter.

Template File Name: DDTRI.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "REAL INPUT"
*
INPUT TABLE, DATA TYPE= REAL
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*"1*" FOR SCHEDULING.
*1*  SCHEDULE  BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*  POINT RECORD= *A9*      PARAMETER= *A9*      PSP?= N  *Y/N*
*1*  LF SUBST?= N *Y/N*
  USE TEST?= N *Y/N*  TEST VALUE= *F*
  BV SUBST?= N *N-No,  C-CONSTANT*      CONSTANT= *F*
  ALGOA= *0-5*  *ALGO 1-5* K1= *F*      *ALGO 5* K2= *F*
  LIMIT CK?=N *Y/N*
    LOW LIMIT= *F*      CLAMP LOW?= N *Y/N*
    HI  LIMIT= *F*      CLAMP HI? = N *Y/N*
```

4.3.2 Input-Integer

Used to build a DDT table entry to "fetch" an integer value from a TDC 3000^X point parameter.

Template File Name: DDTII.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "INTEGER INPUT"
*
INPUT TABLE, DATA TYPE= INTEGER
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*"1*" FOR SCHEDULING.
*1*  SCHEDULE  BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*  POINT RECORD= *A9*      PARAMETER= *A9*      PSP?= N  *Y/N*
*1*  LF SUBST?= N *Y/N*
  USE TEST?= N *Y/N*  TEST VALUE= *I*
  BV SUBST?= N *N-No,  C-CONSTANT*      CONSTANT= *I*
```

4.3.3 Input-ASCII

Used to build a DDT table entry to "fetch" an ASCII value from a TDC 3000^X point parameter.

Template File Name: DDTAI.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ASCII INPUT"
*
INPUT TABLE, DATA TYPE= ASCII
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
  USE TEST?= N *Y/N*    TEST VALUE= *A24*
```

4.3.4 Input-Enumeration

Used to build a DDT table entry to "fetch" an enumeration value from a TDC 3000^X point parameter.

Template File Name: DDTEI.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ENUMERATION INPUT"
*
INPUT TABLE, DATA TYPE= ENUMER
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
* OPTION: SELECT BY REMOVING THE "*1*" FOR SCHEDULING.
*1* SCHEDULE   BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*   POINT RECORD= *A9*      PARAMETER= *A9*    PSP?= N  *Y/N*
*1*       LF SUBST?= N *Y/N*
  USE TEST?= N *Y/N*    TEST VALUE= *A24*
  ENUMERATION SET ID= *A8*
```

4.3.5 Input-Ordinal

Used to build a DDT table entry to "fetch" an ordinal value of an enumeration from a TDC 3000^X point parameter.

Template File Name: DDTOI.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ORDINAL VALUE INPUT"
*
  INPUT TABLE, DATA TYPE= ORDINAL VALUE
    POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*"1*" FOR SCHEDULING.
*1*  SCHEDULE   BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*    POINT RECORD= *A9*    PARAMETER= *A9*    PSP?= N  *Y/N*
*1*      LF SUBST?= N *Y/N*
    USE TEST?= N *Y/N*  TEST VALUE= *F*
    BV SUBST?= N *N-No,  C-CONSTANT*      CONSTANT= *F*
    ALGOA= *0-5*  *ALGO 1-5* K1= *F*      *ALGO 5* K2= *F*
    LIMIT CK?=N *Y/N*
      LOW LIMIT= *F*      CLAMP LOW?= N *Y/N*
      HI  LIMIT= *F*      CLAMP HI? = N *Y/N*
```


4.4 OUTPUT TABLE TEMPLATES

4.4.1 Output-Real

Used to build a DDT table entry to "store" a real value to a TDC 3000^X point parameter.

Template File Name: DDTRO.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "REAL OUTPUT"
*
  OUTPUT TABLE, DATA TYPE= REAL
    POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*"1*" FOR SCHEDULING.
*1*  SCHEDULE   BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*  POINT RECORD= *A9*      PARAMETER= *A9*      PSP?= N  *Y/N*
    ALGOA= *0-5*  *ALGO 1-5* K1= *F*      *ALGO 5* K2= *F*
    LIMIT CK?=N *Y/N*
      LOW LIMIT= *F*      CLAMP LOW?= N *Y/N*
      HI  LIMIT= *F*      CLAMP HI? = N *Y/N*
    STORE?=G  *G-GOOD, B-BAD, D-DON'T*
```

4.4.2 Output-Integer

Used to build a DDT table entry to "store" an integer value to a TDC 3000^X point parameter.

Template File Name: DDTIO.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "INTEGER OUTPUT"
*
  OUTPUT TABLE, DATA TYPE= INTEGER
    POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*"1*" FOR SCHEDULING.
*1*  SCHEDULE   BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*  POINT RECORD= *A9*      PARAMETER= *A9*
                                STORE?=G  *G-GOOD, D-DON'T*
```

4.4.3 Output-ASCII

Used to build a DDT table entry to "store" an ASCII value to a TDC 3000^X point parameter.

Template File Name: DDTAO.PGTMPL.MEDIA

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ASCII OUTPUT"
*
OUTPUT TABLE, DATA TYPE= ASCII
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
  STORE?=G    *G-GOOD, D-DON'T*
```

4.4.4 Output-Enumeration

Used to build a DDT table entry to "store" an enumeration value to a TDC 3000^X point parameter.

Template File Name: DDTEO.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ENUMERATION OUTPUT"
*
OUTPUT TABLE, DATA TYPE= ENUMER
  POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
* OPTION: SELECT BY REMOVING THE "*1*" FOR SCHEDULING.
*1* SCHEDULE  BASE= *I3* RATE=*I3* PHASE= *I3 OR ANY*
*1* POINT RECORD= *A9*      PARAMETER= *A9*      PSP?= N *Y/N*
  STORE?-G    *G-GOOD, D-DON'T*
  ENUMERATION SET ID= *A8*
```

4.4.5 Output-Ordinal

Used to build a DDT table entry to "store" an ordinal value of an enumeration to a TDC 3000^X point parameter.

Template File Name: DDTOO.PGTMPL.MEDIA

Template form:

```
*
* *   DATA DEFINITION TABLE TEMPLATE FOR "ORDINAL VALUE OUTPUT"
*
  OUTPUT TABLE, DATA TYPE= ORDINAL VALUE
    POINT NAME= *A8*      PARAMETER= *A8*      CIU=1 *I1*
*  OPTION: SELECT BY REMOVING THE "*1*" FOR SCHEDULING.
*1*  SCHEDULE  BASE= *I3*  RATE=*I3* PHASE= *I3 OR ANY*
*1*  POINT RECORD= *A9*      PARAMETER= *A9*  PSP?= N  *Y/N*
    ALGOA= *0-5*  *ALGO 1-5* K1= *F*      *ALGO 5* K2= *F*
    LIMIT CK?=N *Y/N*
      LOW LIMIT= *F*      CLAMP LOW?= N *Y/N*
      HI  LIMIT= *F*      CLAMP HI? = N *Y/N*
    STORE?=G  *G-GOOD, B-BAD, D-DON'T*
```

4.5 OTHER TEMPLATE TYPES

4.5.1 Enumeration Set Definition Template

Defines one enumeration set to be used in DDT enumeration input and output operations. The set provides the necessary transformations between TDC 3000^X ASCII values and 45000 integer equivalents.

Template File Name: DEFES.PGTMPL.MEDIA

Template form:

```
*
* *   ENUMERATION SET DEFINITION TEMPLATE
*
  ENUMERATION SET DEFINITION
    ENUMERATION SET ID= *A8*
*   OPTION: REPEAT THE FOLLOWING RECORD FOR EACH ELEMENT IN THE SET
      ENUMERATION= *A8*      VALUE=*I*
```

4.5.2 Define a DDT Name Template

This must be the first template used in each Named DDT.

Template File Name: DEFDDT.PGTMPL.MEDIA

Template form:

```
*
* *   DATA TABLE NAME DEFINITION TEMPLATE
*
  DEFINE DATA DEFINITION TABLE
    DATA TABLE= *A8*
```

4.5.3 Install an ACP Template

Connects the ACP to an ACIDP in the CG.

Template File Name: INSACP.PGTMPL.MEDIA

Template form:

```
*
* *   ADVANCED CONTROL PROGRAM (ACP) CONFIGURATION TEMPLATE
*
INSTALL ACP
  ACP= *A6*           STATUS=N *N-NORMAL, T-TEST, R-RESTRICTED*
  ACIDP= *A8*         CIU=1 *I1*
```

NOTE

Use NORMAL Status only. If either TEST or RESTRICTED is chosen, the CG ignores cyclic or periodic scheduling for that ACP.

4.5.4 Deletions Template

This template includes options to accomplish the following types of deletions:

1. Single points from scheduled DDTs by CG and by type (input or output).
2. Named DDTs from the DDT directory.
3. Enumeration sets from the enumeration directory
4. Disconnect an ACP from its associated ACIDP. The ACP and ACIDP are not deleted.

Template File Name: DELETE.PGTMPL.MEDIA

Template form:

```
*
* *   DELETE TEMPLATE
*
*
*   SELECT OPTION BY REMOVING THE *N* AND FILLING IN DATA
*
*   NOTE:  MORE THAN ONE ENTRY FOR EACH OPTION CAN BE MADE
*          BY DUPLICATING ALL THE DATA FOR THAT OPTION.
*
*   DELETE POINT FROM DATA DEFINITION TABLE
*1*  DELETE    POINT NAME= *A8*          PARAMETER= *A8*
*1*  CIU=1 *I1*      TYPE= *A6*      *INPUT OR OUTPUT*
*
*   DELETE DATA DEFINITION TABLE
*2*  DELETE    DATA TABLE= *A8*
*
*   DELETE ENUMERATION SET DEFINITION
*3*  DELETE    ENUMERATION SET ID= *A8*
*
*   DELETE ADVANCED CONTROL PROGRAM (ACP)
*4*  DELETE          ACP= *A6*
```

4.5.5 Lists Template

This template consists of the following options:

List Option 1—

- Lists all the phase directories by base and type and the number of points assigned to each.
 - Lists all the entries in the ACP directory.
 - Lists all the entries in the Named DDT directory.
 - Lists all the entries in the Enumeration Set directory.
- (No data entry is expected for List Option 1)

List Option 2—For the requested base and phase

- Lists the phase type (input/output).
- Lists the point name and parameter.
- Lists the CG number.
- Lists the destination/source point record ID and parameter.

List Option 3—For the requested named DDT

- Lists by point type (real input, real output, etc.), point names and parameters.
- Lists the CG number.

List Option 4—For the requested enumeration set

- Lists the name and value for each element within the set.

List Option 5—For the requested ACP

- Lists the ACIDP name.
- Lists the status.
- Lists the CG number.

List Option 6—For the requested LCN point name

- Lists the type, base and phase where point name is referenced.
- Lists the type and named DDT where the point name is referenced.

List Option 7—For the requested PMC/PMX point name

- Lists the type, base and phase where point record ID is referenced.

Template File Name: LIST.PGTMPL.MEDIA

Template form:

```

*
* *   LIST DIRECTORY TABLE DATA TEMPLATE
*
*   SELECT OPTION BY REMOVING THE *N* AND FILLING IN DATA
*
*   LIST PHASE, ACP, NAMED DDT AND ENUMERATION SET DIRECTORIES
*1*   LIST   DIRECTORIES=
*
*   LIST ALL ENTRIES FOR REQUESTED BASE AND PHASE
*2*   LIST   SCHEDULE BASE=  *I3*      PHASE=  *I3*
*
*   LIST ALL ENTRIES FOR REQUESTED NAMED DDT
*3*   LIST   DATA TABLE=  *A8*
*
*   LIST ALL ENTRIES FOR REQUESTED ENUMERATION SET PLUS VALUES
*4*   LIST   ENUMERATION SET ID=  *A8*
*
*   LIST ACP NAME, ACIDP NAME, STATUS AND CIU ASSIGNED
*5*   LIST   ACP=  *A6*
*
*   LIST REFERENCES TO TDC 3000 POINT NAME
*6*   LIST   POINT NAME=  *A8*
*
*   LIST REFERENCES TO PMC/PMX POINT RECORD
*7*   LIST   POINT RECORD=  *A9*
*

```

Note that you can include additional requests for an option by repeating its LIST {name of option}= line.

4.6 TABLE BUILDER USE STEPS

NOTE

Data Definition Tables need to be rebuilt whenever the LCN data base is changed in a significant manner, such as by the rebuild or deletion of data points referenced by that DDT.

The build procedure consists of the following steps:

- Enter the Files IV Editor ("X")
- Copy the desired template or templates into the local file
- Insert the required parameter values, using the editor
- Initiate the build command "PGBLD"

On completion of the build function, PGBLD returns to the editor and displays one of the following messages:

- "PGBLD" COMPLETE, NO ERRORS
- "PGBLD" - FILE ERROR
- "PGBLD" - ERROR, SEE LOCAL FILE
- "DSAC02" - DISC READ/WRITE ERROR

A "FILE" or "DSAC02" error is returned if the build function could not access a FILES IV file or the system disc, respectively. The message **ERROR, SEE LOCAL FILE** indicates an error in the build request; display the local file for specifics. The error information and an explanation is inserted after the template line in error.

CG POINT PREPARATION

Section 5

This section summarizes the requirements for preparation of specialized CG data points that regulate the execution of control programs and hold results of control calculations for exchange with other LCN nodes.

5.1 CG POINT BUILDING OVERVIEW

As explained in Section 2, there are two types of data points that reside in the CG, the Advanced Control Interface Data Point (ACIDP) and the Calculated Results Data Point (CRDP). Both point types can be used to store calculated results that are to be exchanged between the 45000 and other LCN nodes. The ACIDP also contains the parameters that control the scheduling and execution of an associated ACP in the 45000.

Both point types are built at an Operator Station that is running in the Engineering Personality; however, each point that includes data storage must reference a previously-prepared Custom Data Segment (CDS) that defines the special parameters to be added to that point.

5.2 CUSTOM DATA SEGMENT CONSTRUCTION

NOTE

The following information on preparation of Custom Data Segments is intended only as an introduction. Please consult the *Control Language Reference* manual for details of CL program preparation and the *System Control Functions* manual for additional information on Custom Data Segments.

Custom Data Segments allow you to define new (nonstandard) parameters and add them to data points. Once you define new parameters and add them to data points, they can be accessed in the same manner as standard parameters. Up to 10 Custom Data Segments can be associated with any ACIDP or CRDP.

Custom Data Segments are constructed as Control Language (CL) Packages, each consisting of a single CDS. These CL "packages" are compiled then stored on the History Module or on Floppy Disk for use when the individual data points are built. The Data Entity Builder (DEB) is used to add instances of a CDS to one or more data points.

Each CDS consists of a heading plus one or more parameters.

5.2.1 Custom Data Segment Heading

The Custom Data Segment heading consists of the word CUSTOM followed by three optional attribute assignments, which change the default values for Class, Access, and Build Visible for this CDS. Either the standard or heading-specified default values are overridden by any individual parameter attribute assignments. Always use the default value for Class when preparing a CDS to be used with an ACIDP or CRDP.

5.2.2 Custom Data Segment Parameters

Each CDS parameter has a heading that begins with the word PARAMETER followed by an up-to-eight-character name, an optional data type specifier, and an optional character string to be displayed by the DEB. This is followed by a set of optional attribute assignments.

Data Type can be Number, Time, Logical, Enumeration, String, or Data Point Identifier (or single-dimension arrays of any of these). The default data type is Number.

The parameter attributes are:

ACCESS—The Access Attribute defines write access restrictions for the parameter. Read access is never restricted. The access levels are View Only, Operator, Supervisor, Engineer, Program, and Entity Builder. The standard default access level is Engineer. For additional information on parameter access level significance, see the *System Control Functions* manual.

BLD_VISIBLE—This determines whether or not a preset parameter value can be changed at point-build time. The standard default value is Build Visible.

VALUE—The data type of the constant expression must match the parameter's assigned (or default) type. If no value is specified and Not Bld_Visible is specified, a default value is assigned. The default values vary by data type as specified in the *Control Language Reference Manual*.

EU—The Engineering Units attribute is a character string that is displayed with other point parameter information. The default is blanks.

CLASS—For an ACIDP or CRDP CDS, always use the standard default value of General.

5.2.3 Custom Data Segment Example

CUSTOM

```
PARAMETER swdbd1 "switch deadband value"  
TYPE number  
ACCESS engineer  
EU "psi"  
VALUE 0.5  
BLD_VISIBLE
```

```
PARAMETER swdbd2  
EU "psi"  
VALUE 0.5
```

END CUSTOM

Notice that the two parameters generated by this example are identical in all but their names. There is no name associated with the CDS because it is identified by the name of the file into which it is compiled (only one CDS per file).

5.2.4 Custom Data Segment Compilation Recommendation

The CL compiler maintains a library file that includes the names of all nonstandard parameter names used in every CDS ever compiled in your system. This file allows for 1000 names, which is normally more than adequate because any of these parameters can be arrays of values, and a particular name is entered only once no matter how many times it is used by multiple Custom Data Segments.

Once a name is entered into the library file, however, there is no way to delete the name. Because it is not desirable to clutter the file with parameter names that were accidentally mistyped, the compiler does not update the library file unless the compiler directive -UL (Update Library) is invoked. You should obey the following sequence when compiling a CDS:

1. First, compile **without** the -UL directive to ensure that the CDS parameters are free of errors. Every new parameter is followed by an error indicating that the -UL option should be used. If any **other** errors appear, they should be corrected.
2. Recompile **with** the -UL directive to update the system library file with the CDS parameter names. There should not be any errors.

It is a good idea on subsequent recompilations to compile without the -UL directive unless a new parameter name is purposely being added to the CDS. This guards against erroneous additions that might occur if a parameter name is accidentally mistyped while editing the file.

You can see all the parameters that have been defined by using File Manager Utilities to print the system library file &ASY>PARAMETR.SP. The file &ASY>SEGMENTS.SP can be printed to see all CDS file names that have been used. The -UL directive also controls whether CDS file names are entered into the library.

Compiling a CDS does not set aside storage for the parameter values; it simply defines the parameters to the system. The next required step is to build a point that uses the CDS parameters. Once a data point is built, the parameters of the CDS are part of the data point and are undifferentiated from other parameters of the data point.

At this point, you should back up the .SE and .SP files on &ASY and should also checkpoint the CG.

5.3 ACIDP/CRDP POINT BUILDING

CG point data can be recorded on Form *CG88-500* in preparation for the actual point-configuration process. Explanation of the entries is found in the *CG Parameter Reference Dictionary*, and the point-entry process is described in the *Data Entity Builder* manual.

A brief outline of ACIDP/CRDP building follows:

1. From the Engineering Personality Main Menu, select the `COMPUTING MODULE` target in the Point Building column. This calls up the `CM BUILD AND CONFIGURATION` menu.
2. Select the target appropriate to the point type to be built.
3. Enter the desired information into the `CM ACIDP/CRDP POINT ASSIGNMENT` display; save the point data in an IDF and then load the point.

If the point is a CRDP, it must have at least one associated "package," i.e., a CDS. For an ACIDP, any CDS is optional.

NOTE

Before deleting an ACIDP from the CG, you should first uninstall its ACP; otherwise, the 45000 status table incorrectly shows the ACP still to be connected to its ACIDP. There is no other effect from this, and the table is automatically corrected after a restart or if you later do the uninstall.

5.3.1 ACIDP Scheduling Recommendations

Set long `RTPERIOD` values for cyclic and periodic ACPs or set them to demand-only and determine how long they actually run before selecting the normal running period.

If the `RTPERIOD` in an ACIDP is short (close to the time required for the associated ACP to execute), it is difficult or impossible to disconnect the ACIDP or to uninstall the ACP. If this happens, change the parameter `INH_STAT` to `INHIBIT` from the point's Detail Display at a Universal Station. Wait for the ACP to terminate as indicated by a change of Execution State to `DELAY`, then disconnect the ACP from the ACIDP.

5.4 VIEWING AND CHANGING ACIDPS & CRDPS

The current values of certain ACIDP and CRDP parameters can be viewed, and certain scheduling-related parameters can be changed from the area Universal Station in the Operator Personality.

On-line display and change access to ACIDP parameters is summarized in Table 5-1 and to CRDP parameters in Table 5-2.

A brief description of each user-visible parameter sorted by parameter name follows at subsection 5.4.1. See the *CG Parameter Reference Dictionary* for additional details.

Table 5-1 — Display and Change of ACIDP Standard Parameters

Parameter Name	Detail Display		Group Display	
	Display	Change	Display	Change
ABORTCOD	no*	no	no	no
ACCESKEY	yes	no	no	no
ACPROG	yes	no	no	no
ACT_TYPE	yes	no	no	no
CONFWAIT	yes	no	no	no
EXECSTAT	yes	no	yes	no
INH_STAT	yes	operator	no	no
KEYWORD	yes	no	yes	no
NAME	yes	no	yes	no
NEXT_RTM	yes	no	no	no
OPER_DMD	yes**	operator	no	no
PROGSTAT	yes	no	no	no
PTDESC	yes	no	yes***	no
RTPERIOD	yes	no	no	no
RUN_INIT	yes	no	no	no
STIME	yes	no	no	no
* Visible as EXECSTAT value when non-zero ** Target used to request ACP activation *** Only shown when point is selected				

Table 5-2 — Display of CRDP Parameters

Parameter Name	Detail Display		Group Display	
	Display	Change	Display	Change
KEYWORD	yes	no	yes	no
NAME	yes	no	yes	no
PTDESC	yes	no	no	no
UNIT	yes	no	no	no

5.4.1 CG Parameter Descriptions

ABORTCOD—Numeric code (four hexadecimal digits) that indicates the reason for abort of an ACP. When nonzero, this value replaces the EXECSTAT value in the point detail display. See subsection 3.4.2 of this manual for explanation of abort code value assignments.

ACCESKEY—Determines whether or not the ACP can execute writes to the LCN. Values are READWRIT or READONLY.

ACPROG—The program name of the ACP as stored in the 45000.

ACT_TYPE—The activation method for the ACP. Values are CYCLIC, PERIODIC, CYC_DMD, PER_DMD, DEMAND.

CONFWAIT—Time (in seconds) remaining before a pending message confirmation times out. (Equal to zero when CONF RQD equals OFF.)

EXECSTAT—The present execution state of the ACP. Values are ABORT, ACCESS, DELAY, OFF, RUN, WAIT, FAIL. When state is ABORT, the detail display shows the current value for ABORTCOD.

INH_STAT—An operator-changeable parameter that controls activation of the ACP. Values are INHIBIT or PERMIT.

KEYWORD—Name shown on Universal Station displays.

NAME—Name of the ACIDP/CRDP.

NEXT_RTM—Next run time, used by both Periodic and Cyclic activation. The parameter is in form HH:MM:SSbMM:DD:YYb (where "b" indicates a space). Blank if activation type is demand-only.

OPER_DMD—An operator-accessible parameter, which when set ON turns on the ACP if its activation type permits demand activation and ABORTCOD = 0. (See the *Computer Gateway Parameter Reference Dictionary* for effect of OPER_DMD on an Aborted ACP.)

PROGSTAT—Installation mode of the ACP. Values are NOT INST, TEST, RESTRICT, NORMAL.

PTDESC—Description of the variable.

RTPERIOD—The time period between runs of a scheduled ACP, in format HH:MM:SS. Minimum period is 10 seconds; maximum period is 24 hours. Not used if ACP activation is demand-only.

RUN_INIT—When ON, tells the scheduler to turn on the ACP immediately after an "initialization event" (see note below).

STIME—The first time of day that a periodic program runs, in format HH:MM:SS. The maximum time is 24:00:00. STIME must be less-than or equal-to RTPERIOD. Not used if ACP activation is cyclic, cyclic-demand, or demand.

NOTE

There are three initialization event types:

- 1 – CG power up and software load (cold restart)
- 2 – 45000 initialization or data-link restart (warm restart)
- 3 – ACIDP initialization
 - a) Connecting an ACP using ACP Installer (PGBLD)
 - b) Removing an Abort condition from an ACP by operator action

SYSTEM STARTUP Section 6

This section contains information on system startup and failure restarts.

6.1 STARTUP

Startup involves separate preparation of the CG and of the 45000 in a series of steps that configure them to the unique requirements of your system.

6.1.1 Preparing the CG

Follow the configuration steps outlined at subsection 2.5.1, then install ACIDPs and CRDPs according to Section 5.

6.1.1.1 System Interface ACIDP

The PGDCP program uses one ACIDP in each configured CG for processing of the Scheduled DDTs. The ACIDP names are of your choice, but each must be connected to PGDCP by use of PGBLD.

When building the ACIDP (see subsection 5.3) to be used by PGDCP, the following parameter values are required:

```
ACCESKEY = READWRIT
ACT_TYPE = DEMAND
RUN_INIT = ON
```

Once the ACIDP is built and installed, PGDCP can be connected to it (see subsection 4.5.3). Its ACPROG value then becomes PGDCP and its PROGSTAT becomes NORMAL.

Before Scheduled DDTs can run, it is necessary for the INH_STAT parameter of the ACIDP connected to PGDCP to be set to PERMIT through its Detail Display at the Universal Station.

6.1.2 Preparing the 45000

6.1.2.1 Processor Gateway Software Checklist

The following label names are included in the PG checklist that is used to define PG interface software parameters to the 45000 computer:

TYP SYS— 0=PMC, 1=PMX. Defines the type of system to the PGBLD and PGDCP programs. Required because of PMC/PMX data-base access differences.

TYP PMX— 0=PMC/PMXII, 1=PMXIII. Defines the type of PMX system.

- RLSTYP**— 0=before Release 300, 1=Release 300 or later. Defines the software release level of the TDC 3000^X LCN nodes.
- PGDCP**—The real-time program number assigned to the PGDCP program. This requires an available slot in the PROG table with a reasonably high priority. On PMX, this is assigned in the P0.CKLST.
- PGPTR**—The address of the lower main-memory pointer to the upper main memory. This requires one word, plus four words for each CG connected to the 45000. On PMX, this is assigned in the P0.CKLST.
- PGBLKX**—The bulk address of the programs and routines (for PMC on logical device 3 and for PMX on logical device zero). On PMX, this is assigned in the P0.CKLST.
- PGCLD**—PMC=3, PMX=7. Logical bulk device containing the PG database.
- PGBLKS**—The starting bulk address of the PG database
 PMC – /20000000
 PMX – Assigned in the configuration with an alter to SUPBK2.BASE2 for PMXII Rel 2 or to SUPBK2.BASE3 for PMXIII.
 See subsection 6.1.2.3.
- PGBLKE**—The ending bulk address of the PG database
 PMC – /40000000
 PMX – Assigned in the configuration with an alter to SUPBK2.BASE2 for PMXII Rel 2 or to SUPBK2.BASE3 for PMXIII.
 See subsection 6.1.2.3.
- PGCCIU**—The number of CIUs (CGs) connected to the 45000.
- PGRAD1**—The TSDL receiver address for CG #1.
- PGRAD2**—The TSDL receiver address for CG #2.
- PGCPHA**—PMC=600, PMX=120. The number of VARPR phases.
- PGCVP1**—PMC=1, PMX=1/5/15/60. The VARPR-1 processing rate.
- PGCVP2**—PMC=1, PMX=1/5/15/60. The VARPR-2 processing rate.
- PGCSC1**—The DDT scheduler-1 processing rate in seconds - 15/30/60/120.
- PGCSC2**—The DDT scheduler-2 processing rate in seconds - 15/30/60/120.
- SC1VP1**—The DDT scheduler-1 processing rate (PGCSC1) divided by the VARPR-1 processing rate (PGCVP1).
- SC2VP2**—The DDT scheduler-2 processing rate (PGCSC2) divided by the VARPR-2 processing rate (PGCVP2).
- PH1SC1**—The number of VARPR phases (PGCPHA) divided by SC1VP1.
- PH2SC2**—The number of VARPR phases (PGCPHA) divided by SC2VP2.

SC1PHA—The same value as PH1SC1 (number of phases in rate 1).

SC2PHA—The same value as PH1SC2 (number of phases in rate 2).

Following is a list of the allowable entries in a PMC/PMX system configured for /20000000 words for the PG data base and programs. Each entry is referred to in pages (/2000 words per page).

MAIN DIRECTORY—Provides page pointers to the other directories. It consists of one page.

PHASE MAPPING—Provides phase DDT page pointers and phase entry counters. It consists of one page.

INSTALLED ACPs—Directory in which 254 ACPs can be installed. It consists of two pages (127 ACPs per page).

ENUMERATION SETS—Directory in which 255 sets can be defined. It consists of one page. Each set uses one page with 255 entries per page.

NAMED DDTs—Directory uses two pages with 255 entries on each page. Each entry uses five pages with a maximum of 300 points defined for each named DDT entry.

SCHEDULED DDTs—The number of scheduled DDTs is calculated from the base 1 and base 2 VARPR processing rates, the base 1 and base 2 DDT scheduler processing rates, and the number of phases in the PMC/PMX system. Each entry uses five pages, with a maximum of 300 points possible for each scheduled DDT entry.

The number of scheduled DDTs for either PMC or PMX is determined by dividing each DDT scheduler rate (PGCSC1 or PGCSC2) by the corresponding VARPR processing rate (PGCVP1 or PGCVP2) to determine DDT rate (SC1VP1 or SC2VP2). The DDT rates are then divided into the number of system phases (PMC=600, PMX=120) and the results added to determine the number of internal phase tables for input/output DDTs.

For example, given the following:

VARPR Processing rates PGCVP1=1 and PGCVP2=30

DDT scheduler processing rates PGCSC1=15 and PGCSC2=60

PMC (600 phases) creates:

$PCGSC1/PGCVP1 = 15/1 = 15 = SC1VP1$

$PCGSC2/PGCVP2 = 60/30 = 2 = SC2VP2$

$PGCPHA/SC1VP1 = 600/15 = 40 = PH1SC1$

$PGCPHA/SC2VP2 = 600/2 = 300 = PH2SC2$

$PH1SC1 + PH2SC2 = 40 + 300 = 340$ phase tables for I/O DDTs

PMX (120 phases) creates:

$PCGSC1/PGCVP1 = 15/1 = 15 = SC1VP1$

$PCGSC2/PGCVP2 = 60/30 = 2 = SC2VP2$

$PGCPHA/SC1VP1 = 120/15 = 8 = PH1SC1$

$PGCPHA/SC2VP2 = 120/2 = 60 = PH2SC2$

$PH1SC1 + PH2SC2 = 8 + 60 = 68$ phase tables for I/O DDTs

REFERENCE TABLE—Directory that uses 256 pages that contain a composite of all the unique TDC 3000^X point names and parameters from the named DDTs and the scheduled DDTs.

6.1.2.2 PG Implementation Steps on a PMC System

A) Create a new file system on logical device number 3.

- Mount the PMC Total V0 and V1 packs and bring on-line.
- Remove any existing files that may be on LD3
- Using CFSYS, create a new file system for the lower half of LD3 for /20000000 words (/4000 words used as FILES IV pointer words).
- Upper /20000000 words to be used for the PG software and database.

Using Freetime program CFSYS do the following:
(The symbols < > indicate an Operator entry and they should not be entered).

```
1151 ENTER
<CFSYS>
LOGICAL DEVICE NUMBER? I2
<03>
SETUP POINTER WORDS? YN
<Y>
START ADDR? 08
<00004000>
SIZE? 08
<17774000>
MEDIA ID? 15
<75133>
WARNING--PROGRAM WILL DESTROY MASTER CATALOG
FS POINTER WDS=MEDIA ID D75133 ADDR-00004000 SIZE-17774000
CREATE NEW FILE SYSTEM? YN
<Y>
(A6) M-CAT PASS
<MASTER>
(14) FILES
<2000>
CREATE NEW FILE SYSTEM? YN
<Y>
ENDJOB
```

B) Move files to the source pack. Mount the PG floppy D00001. Bring V4 on line with the MC program, and execute PMC.MOVE.V4 read file.

NOTE

All Processor Gateway source files must exist on the system source pack before you start this procedure. Normally, this is media D75133 or V3.

C) Edit PG Checklist.

1. Mount the PMC packs on V0 and V1 and bring the drives on-line.
2. Use PGCLST.PGSORC to edit the checklist.
3. Define the lower memory words.
The number of words = $((4 * \text{number of CGs}) + 1)$. For example, one CG requires five words.
4. Define a spare, relative high, program number for PGDCP in PGCLST.PGSORC.

D) Assemble the PG Checklist and Programs.

1. Run the PGCONF.GENPMC read file.

E) Load to PMC 450 target system (must be at latest revision level).

1. Use the read file PG.LODPMC to load software onto the system.
2. If you are loading the PG subsystem for the first time, you must also initialize the PG database. Use the read file PGINZ.LODPMC to initialize the PG database.

6.1.2.3 PG Implementation Steps on a PMX System

NOTE

All Processor Gateway software must exist on the system source pack (D50910/11 for PMXII, Rel 2, or D60910/11 for PMXIII, or D70910/11 for PMX IV) prior to starting this procedure.

In the following instructions, the word **MEDIA** refers to D50910/11, D60910/11, or D70910/11 depending on the PMX system type (PMX II, III or IV).

A) Move files to source pack for PMX system. Mount the PG floppy D00001. In FILES IV, execute REA PMXn.MOVE.D00001 (where n=2, 3, 4*) read file.

B) Modify PMX Programs and Tables

1. Use RLDMAP.PGALTR.MEDIA(RLDMAP.PGALT4 for PMX IV) to modify RLDMAP so that the data link request, driver, and servicing programs are mapped into upper memory and the interrupt linkage and upper memory pointer are mapped into lower memory. The PGDCP program is to be mapped in and run as a permanent memory program.
2. Use SUPBK2.PGALTR.MEDIA to modify SUPBK2 so that when the configuration is done, the bulk area for the DDTs is configured on logical device 7.

3. Modify the P0.CKLST for the system configuration and add the following PG constants:

- We recommend that logical device seven reside on physical device one.
- For MEMLOW, DESC=PGPTR; number of words = 5
- BULK0=/40000, DESC=PGBLKX. Bulk allocation for PG programs.
- SYMBOL=PGDCP, value=86. Program number for PGDCP.
- SYMBOL=PGCCIU, value=1. Number of CGs to configure.
- TURNON=86. Program number to turn on at reload; must be number of PGDCP.

4. Configure the system using the standard PMX configuration.

- In Files IV, execute DO MEMOR2.PGPMXn.MEDIA (!OPTIONmA!)
(where n = 2, 3, 4* and m = 1, 2**)

C) Edit PG Checklist

1. In FILES IV, use PGXLST.PGSORC.MEDIA to edit the checklist.

D) Assemble PG Configuration file

1. Execute read file. PGCONF.GENPXn.MEDIA where n = 2, 3, 4*

E) Load to target system

1. Execute read file PG.LODPXn.MEDIA where n = 2, 3, 4* to load software.

NOTE

If loading PG subsystem for the first time you must also initialize the PG database. Execute read file PGINZ.LODPXn.MEDIA where n = 2, 3, 4* to initialize the PG database.

6.1.2.4 TSDL Pinning Options

Clock source selection on the PTSB1 board is dependent on the type of cable used between the 45000 and the CG. Refer to your system SS5 for details.

*Where n is defined as follows: 2 = PMX II Rel. 2, 3 = PMX III, 4 = PMX IV.

*Where m is defined as 1 for the database maintained or 2 for the database initialized.

6.2 RESTART MODES

Responsibility for establishing communication between the CG and 45000 is left to the CG. Whenever the CG is freshly loaded it attempts to make a Cold Restart. If communications with the 45000 are interrupted following a successful Cold Restart, the CG then attempts a Warm Restart.

In either instance, the major purpose of restart is to resolve any mismatch of databases between the CG and 45000. Upon completion of restart, the 45000 prints a restart message on the system I/O typer and the CG begins scheduling of ACPs.

If communication is broken at any time, the CG waits for two minutes before trying again. Some failures may require reload of the CG.

6.3 DATA LINK STATUS INFORMATION

The CG holds data link status information in its Processor Status data point. To view this data, place the point \$PRSTSnn (where nn is the CG node number) in a custom schematic display. The three data link status parameters of this point and their value meanings are

- ULP_STS = IN_SERV**—Communications with the 45000 have been established. This value is set when Restart is complete.
- =FAILED**—Communications with the 45000 are broken. This value is set when both links have failed.

- DL1_STS = IN_SERV**—Link 1 has been connected and the CG is using or trying to use the link.
- =FAILED**—The CG has disconnected Link 1 because of problems.

- DL2_STS = IN_SERV**—Link 2 has been connected and the CG is using or trying to use the link.
- =FAILED**—The CG has disconnected Link 2 because of problems.
- =NOT_INST**—The CG has been configured for operation on Link 1 only.

STATUS CODES

Appendix A

This appendix lists the status codes that are returned following data exchanges.

A.1 DATA ACCESS STATUS CODES

The following LCN data access status codes apply to the individual point parameters, and are included in the data returned to the ACP by the user interface routines.

Code	Explanation
1	Value out of range, clamped value stored and clamped value returned
2	String was too long, truncated value was stored
3	Initialization warning
4	End of history data file
5	End of user-specified samples or time
6	User-allocated buffer is full
7	Spare warning 05
8	Data item is valid
9	Access level invalid (HG)
10	Invalid algorithm for controller type
11	Algorithm must be DDC (tried op store)
12	Algorithm must be SPC (tried sp store)
13	Value type presented for store was not the expected type
14	Bias is undergoing initialization
15	Both init and tracking cannot be configured
16	HG box status is failed
17	HG box not configured
18	Mode must be manual
19	Cannot convert numeric variable to IEEE
20	Cannot convert numeric variable to JFP
21	Cannot reset timer unless stopped
22	Cascade request flag must be set
23	Change not permitted by operator
24	Cascade enable flag must be set (for change to computer mode)
25	Configuration mismatch error
26	Control output connection not configured
27	Current mode disallows mode change
28	Current mode disallows store
29	Failure of device where entity resides
30	Device where entity resides is in reset
31	Engineering unit span is too small
32	Given subscript is not implemented in entity
33	External mode switching is enabled
34	External switching option is not selected

- 35 Fatal error: no match for case selector
- 36 HG hiway status is failed
- 37 Hiway access failure
- 38 Illegal value
- 39 Init cannot be configured
- 40 Init must be configured
- 41 Value cannot be changed because of initialization
- 42 Invalid internal variable number
- 43 Invalid algorithm ID in base segment
- 44 Invalid algorithm equation
- 45 Invalid control algorithm ID error
- 46 Invalid destination parameter
- 47 Invalid destination point ID
- 48 Invalid mode
- 49 Invalid mode attribute
- 50 Invalid pb option
- 51 Invalid point for point build
- 52 Invalid sp option
- 53 Invalid target value processor state
- 54 Max structural parameter exceeded error
- 55 Mode attribute error
- 56 Invalid PV control algorithm combination
- 57 Duplicate batch ID
- 58 Current mode does not allow parameter value to be changed
- 59 Mode illegal for this point type
- 60 Mode keylock error
- 61 Mode not allowed with configured algo
- 62 Mode not currently legal
- 63 Mode not man or point active
- 64 Must have digital output
- 65 Currently there is no value for this parameter
- 66 Nocopts must be zero to change copctype
- 67 Normal attribute is not configured
- 68 Normal mode is not configured
- 69 Value cannot be changed, because parameter is not selected
- 70 Number of outputs must exceed zero
- 71 Entry only possible in off-process personality
- 72 Output is undergoing initialization
- 73 Operator override is required for store
- 74 Parameter cannot be changed
- 75 Parameter index is invalid
- 76 Parameter is invalid
- 77 Parameter is undergoing initialization
- 78 Parameter is not configured
- 79 Parameter is not valid for the configured control algorithm
- 80 Parameter is not valid for the configured pv algorithm
- 81 Status of entity is partial error
- 82 Point must be inactive
- 83 Point is red tagged
- 84 Point is undergoing initialization
- 85 Point is not available to point build
- 86 Definition of point is not complete enough to make point valid

- 87 Point not secondary
- 88 Point status error (HG status is in error)
- 89 Point type is invalid (HG configuration error)
- 90 PPS only active points error
- 91 Process box restore in operation
- 92 Process module off
- 93 PV source disallows PV change (HG cannot change PV)
- 94 Ratio is undergoing initialization
- 95 Read only parameter (HG cannot write)
- 96 Red tag error (all output entries are blocked)
- 97 Secondary has too many primaries
- 98 Secondary must be off node
- 99 Secondary point has no primary
- 100 HG slot number invalid
- 101 Source of request is invalid (HG change is prohibited)
- 102 Source of Y is not configured (HG change to casc mode is invalid)
- 103 SP is undergoing initialization
- 104 SP is undergoing pvtracking
- 105 Store not allowed with spc connection
- 106 Store not permitted
- 107 Store not permitted from off point
- 108 Subscript error
- 109 System error (HG data handler detected)
- 110 Tracking cannot be configured
- 111 Entry prohibited because of tracking
- 112 Tracking must be configured
- 113 Spare error 3
- 114 Y cannot be configured to own LSP
- 115 Point type id error
- 116 Segment class error
- 117 Invalid control algorithm error
- 118 Invalid pv algorithm error
- 119 Segment size exceeds maximum segment size
- 120 Memory unavailable
- 121 Get memory error
- 122 Structural parameter missing
- 123 Structural parameter maximum violated
- 124 Invalid cc rank
- 125 Store not permitted while casreq
- 126 Analog output used for modulating control
- 127 Y must be configured to own lsp
- 128 Store not permitted unless free variable
- 129 Control lock error
- 130 Point not primary
- 131 Off node parameter access error
- 132 Memory allocation error
- 133 Unit mismatch
- 134 Point must be scheduled
- 135 Before after period incompatible
- 136 Integer value required
- 137 Invalid PV equation
- 138 Invalid ctl equation
- 139 Invalid number of PV inputs
- 140 Invalid number of ctl inputs

- 141 Invalid number of ctl outputs
- 142 Invalid pv algorithm id
- 143 Invalid ctl algorithm id
- 144 Invalid pv algorithm
- 145 Invalid ctl algorithm
- 146 Invalid rb option
- 147 PV algorithm ID cannot be null
- 148 CTL algorithm ID cannot be null
- 149 PV algorithm ID structural parameter fetch error
- 150 CTL algorithm ID structural parameter fetch error
- 151 RB option structural parameter fetch error
- 152 SP option structural parameter fetch error
- 153 PV equation structural parameter fetch error
- 154 Control equation structural parameter fetch error
- 155 Number of pv inputs structural parameter fetch error
- 156 Number of ctl inputs structural parameter fetch error
- 157 Number of ctl outputs structural parameter fetch error
- 158 Copctype structural parameter fetch error
- 159 Structural parameter fetch error
- 160 Invalid structural parameter
- 161 Configuration error
- 162 Number of ctl outputs is zero
- 163 Fetch not permitted
- 164 Change restricted to engineering personality
- 165 Change restricted to on process personality
- 166 Access level error
- 167 Attribute ID error
- 168 Function level error
- 169 Parameter ID error
- 170 Parameter qualifier type error
- 171 Parameter type invalid
- 172 Prefetch item error
- 173 Data type error
- 174 Rev 20 disallows both SOPL and trend memory
- 175 Limit or range exceeded
- 176 Limit or range crossover
- 177 Inconsistent lrc for point build
- 178 Point build HG only
- 179 Must configure enough cl slots for standard actions
- 180 Point must be inactive or ready
- 181 Point not active or not configured in a History Group
- 182 No batch slot or no slot of sufficient size is available
- 183 Number of concurrent batches not established
- 184 Only active or inactive allowed
- 185 Prototype must have cls to be cloned
- 186 Only one dual output store permitted per request
- 187 Illegal timer state
- 188 Illegal counter state
- 189 Invalid number of ainpts
- 190 Invalid number of ordstns
- 191 Invalid number of orvals
- 192 Spare error 4
- 193 Alarm configuration mismatch
- 194 Control state read error

195	Control state basic error
196	Control state test error
197	Input and output required
198	Input and output box mismatch
199	Current state disallows operational state change
200	Configuration forcing in effect
201	Current procmod disallows store
202	Device must be in idle
203	Device must be in reset
204	Illegal box protocol
205	Invalid box status
206	Invalid characterization type
207	Invalid database index
208	Parameter not loaded
209	PV source invalid
210	Event overload
211	SP lock error
212	Improper access level
213	Invalid attribute ID
214	No such entity ID
215	No such function level in data owner
216	Initialization value
217	Communication path to data owner is disabled
218	Invalid parameter ID
219	Improper parameter qualifier type
220	Given parameter type is invalid for the requested operation
221	Prefetch item number
222	Serial number in point id does not match
223	Value type presented for store was not of the expected type
224	Invalid store value supplied
225	Subscript out of range
226	Unable to perform specified limit check on store value
227	Value out of range, store not performed
228	Path to parameter cannot be completed
229	Spare error 14
230	Spare error 15
240	Illegal No Good store
241	Input status table error
242	Point not in history
243	Enum convert failure
244	SDE store not allowed
245	ACP value bad
246	Subst value bad
247	Bad Algo
248	Div by zero
249	Limit exceeded
250	Real value NaN
251	Data error
252	Wrong data type
253	Get set error
254	Get IDB item error
255	Directed no store (Not an error. Returned for all store data elements whose store code value is not 0 or 1.)

RUN TIME ERROR MESSAGES

Appendix B

The following error messages can be output to the 45000 system typer (DTYPER) by the PGDCP program.

- PROCESSOR GATEWAY ACP REQUEST ERROR, SYSTEM NOT INITIT
System time has not been entered.
- PROCESSOR GATEWAY ACP REQUEST ERROR, NOT IN LIBRARY, ACIDP = {name}
The named ACIDP requested execution of an ACP that is not in the FREETIME library.
- PROCESSOR GATEWAY ACP REQUEST ERROR, NO-JOB STATUS, ACIDP = {name}
The named ACIDP requested the execution of an ACP that is in the "NO-JOB" status in the FREETIME library.
- PROCESSOR GATEWAY ACP REQUEST ERROR, TEST STATUS, ACIDP = {name}
The named ACIDP requested the execution of an ACP that is in the "TEST" status in the FREETIME library.
- PROCESSOR GATEWAY ACP REQUEST ERROR, NOT INSTALLED, ACIDP = {name}
The named ACIDP requested the execution of an ACP that is not in the ACP directory. The ACP has not been installed through the PGBLD program.
- PROCESSOR GATEWAY ACP REQUEST ERROR, TOO MANY ACTIVE, ACIDP = {name}
The named ACIDP requested the execution of an ACP when there were too many active requests for the system to be able to schedule additional requests. This can be indirectly caused by an ACP that does not use PRGTRM when it terminates execution.
- PROCESSOR GATEWAY ACP REQUEST ERROR, ALREADY ACTIVE, ADIDP = {name}
The named ACIDP requested the execution of an ACP that is already active.
- PROCESSOR GATEWAY CIU #n LCN ACCESS ERROR nnn
A request was made by a Scheduled DDT to the identified CG (#n), and an access error code (nnn) was returned. These error codes are defined in the *Computer Gateway User's Manual* in the *Implementation/Computer Gateway* binder, with the descriptions of the Get Data Return message and the Store Data Return message.

- PROCESSOR GATEWAY DDT SCHEDULLER nnn PHASES BEHIND

The PGDCP program is (nnn) phases behind in processing the scheduled DDT tables. This message appears when 10 phases behind and at each additional multiple of 10. This can be caused by too many DDT table entries or the total number of scheduled DDTs and ACP requests exceed the system limit.

- PROCESSOR GATEWAY SCHEDULED DDT ERROR #nnn
ON TAG nnnnnnnn pppppppp (sss)

The PGDCP program received the Data Access Status code (nnn) that indicates an error when accessing the identified point.parameter (nnnnnnnn.pppppppp (sss)) for a scheduled DDT. An error message is not repeated for a given point.parameter until an intervening nonerror status return for that point.parameter is received. For named DDTs these codes are returned to the ACP program with the data. The Data Access Status codes are defined in Appendix A of this manual.

- PROCESSOR GATEWAY DSAERR xxx AT REL nnnnn

The PGDCP program received the error code (xxx) when accessing bulk storage. The relative location (nnnnn) is the program location where the request was made. When a bulk error is encountered, the PGDCP program aborts all requests and terminates execution.

- PROCESSOR GATEWAY DATA LINK #nn FAILURE 00x

The PGDCP program is unable to communicate over data link (nn). The failure reasons (00x) are:

- 001 = Response message timeout
- 002 = Message confirmation output error
- 003 = Control block output error
- 004 = Message input error
- 005 = Scheduler behind error

- PROCESSOR GATEWAY DATA LINK #nn RESTART

The PGDCP program has received a restart message for data link (nn).

- PROCESSOR GATEWAY V3.X::: DDT SCHEDULER TURNED ON - CIU #n

The PGDCP program has received the scheduled DDT turn on message from CG number (n). V3.X indicates the present version of the Processor Gateway software

CG CAPACITIES SUMMARY

Appendix C

This appendix summarizes the most important size and timing limits of the CG.

The values shown are permissible limits. The actual limits may be less depending on the combination of elements in a given data base.

CG DATA BASE LIMITS

ACIDPs per CG	250
CRDPs per CG	500
Units assigned to a CG	63
Points per Input or Output DDT	300

CG SCHEDULING LIMITS FOR ACPS

Cyclic Program Run Intervals	10 seconds minimum, 24 hours maximum
------------------------------	---

MESSAGE SIZE LIMITS

For display	60 characters
For printing	72 characters
For archiving	120 characters

CUSTOM DATA SEGMENT LIMITS

CDS Parameter names	1000 per system
CDS per ACIDP or CRDP	10

THROUGHPUT

Maximum parameters per second	30
-------------------------------	----

CG MEMORY USE ESTIMATING

There are approximately 400,000 16-bit words available to be shared by ACIDPs and CRDPs (and their associated Custom Data Segments) and the CG-resident Get Data DDTs.

The average number of words required for each of these is:

ACIDP—144 words

CRDP—72 words

DDT— $40 + 6 * (\text{the number of parameters})$ words

CDS—Each Custom Data Segment consists of a descriptor segment and the segment itself. The descriptor file requires $13 + 22 * (\text{the number of parameters})$ words, while segment sizes vary with the mix of parameter types.

Each Real parameter requires 2 words

Each ASCII parameter requires 12 words

Each Enumeration parameter requires 1 word

Each Self-defining enumeration requires 4 words

Each Boolean parameter requires 1 word

ASSIGNMENT OF PROCESS UNITS TO CG

Appendix D

This appendix contains information relating to the assignment of process units to the CG.

1. The number of process units that can be assigned to a CG is 63 minus the number of CGs assigned to the same checkpoint volume. For example, if you have two CGs assigned to one HM for checkpointing, there can be no more than 61 units assigned.
2. Because the CG node status display shows only points that are assigned to its area and to the CG node, you can never see more than 36 (area limit).
3. ACP access to parameters in other LCN nodes, both read and write, is independent of which units are assigned to the CG. That is, it does not matter to which unit the ACP's ACIDP is assigned.
4. Event-Initiated Processing from the HG and CL Messages from the AM and MC are independent of process unit assignment in the CG.
5. The operator demand of an ACP from its ACIDP detail display requires that the ACIDP is in a unit assigned to that Universal Station's area, or that the US is in Engineer keylock level. The same limitation applies to any CG point parameter that you may wish to store to from a custom display.
6. An ACP can send an operator message to only the Unit its ACIDP is assigned to. Thus, only areas with that unit assigned will receive the message.
7. A process unit can be assigned to only one CG. If there are multiple CGs on the LCN, each must have a unique assignment of process units.

To summarize, for most flexibility, all units assigned to CGs should be assigned to all areas that need to communicate with that CG. There is no need for a CG to have assigned to it any of the units that the points that it accesses reside in.

In most cases, there is no real need to assign more than one unit to a CG.

Index

Topic	Section Heading
45000 Computer	1.1, 1.2
Access of TDC 3000 ^X Data	2.1 - 2.4
ACPs in	1.2
Cyclic exchange of data	2.2
PMC/PMX Applications	Section 2 (Preface)
Preparing	6.1.2
Scheduling of ACP by	2.3.1
Software Checklist	6.1.2.1
45000/PMC/PMX Publications	1.3
Abort Alarm	2.3.3.2
Abort State	2.3.2.1, 2.3.2.2
ABORTCOD (CG Parameter)	3.4.2, 5.4 - Table 5-1, 5.4.1
ACCESKEY (CG Parameter)	5.4 - Table 5-1, 5.4.1, 6.1.1.1
ACCESS (Custom Data Segment Attribute)	5.2.2
ACIDP	
Changing	5.4
Display and Change of Standard Parameters	5.4 - Table 5-1
Point Building	5.3
Scheduling Recommendations	5.3.1
System Interface	6.1.1.1
as Template value entry	4.2.1
Viewing and Changing	5.4
ACP — <i>See also Advanced Control Program</i>	
CG Scheduling Limits for	Appendix C
Compilation	2.5.4
Computer Operator Interfaces	2.3.3.2
Defined	1.2, 2.3
Execution Example	2.3.4
Get ACP Status	3.4.1
Implementation Steps	2.5
Inhibit ACP Activation	2.3.2.3
Initiation of	2.3.1 - Table 2-1
Installation	2.5.4
Installation Modes	2.3.1
Interface Subroutines	Section 3
Normal-mode scheduling of ACPs	2.3.2.1
Periodic and Cyclic Scheduling	2.3.2.1
Process Operator Interfaces	2.3.3.1
Program Activation	2.3.2.1
Scheduling by the CG	2.3.2
Scheduling Capabilities	2.3.1 - Table 2-1
Template, Installing	4.5.3
as Template value entry	4.2.1
Termination Interface	2.3.2.2, 3.4.2
ACPROG (CG Parameter)	5.4 - Table 5-1, 5.4.1, 6.1.1.1
ACT_TYPE (CG Parameter)	5.4 - Table 5-1, 5.4.1, 6.1.1.1

Index

Topic	Section Heading
Address	
External	2.1
Internal	2.1
Advanced Control Interface Data Point — <i>See ACIDP</i>	
Advanced Control Program (ACP)	
Cleanup stage	2.3
Defined	2.3
Run stage	2.3
Setup stage	2.3
Special interface subroutines	2.3
ALGOA, as Template value entry	4.2.1
Array Compatibility	3.1.3
ASCII data format	3.1.2
ASCII Input Template	4.3.3
Assemble PG Checklist and Programs	
for PMC	6.1.2.2
for PMX	6.1.2.3
Assignment of Process Units to CG	Appendix D
BAD VALUE — <i>See also BV SUBST?</i>	4.2.1
BLD_VISIBLE, Custom Data Segment Attribute	5.2.2
Builder Program, PGBLD	2.4
Uses of	2.4
BV SUBST?, as Template value entry	4.2.1
Calculated Results Data Point — <i>See CRDP</i>	
CDS — <i>See Custom Data Segment</i>	
CG — <i>See also Computer Gateway</i>	
Assignment of Process Units to	Appendix D
Capacities Summary	Appendix C
Checkpointing	5.2.4
Configuration	2.5.1
Configuration display	2.5.1
Data Base Limits	Appendix C
Inhibit (ACP) Program	2.3.2.3
Memory Use Estimating	Appendix C
Parameter Descriptions	5.4.1
<i>CG Parameter Reference Dictionary</i>	2.3.2, 2.5.1, 5.3, 5.4
Point Building Overview	5.1
Point Preparation	Section 5
Preparing	6.1.1
Program Termination	2.3.2.2
Scheduling ACP	2.3.2
Operator Demand	2.3.2.1
Periodic and Cyclic	2.3.2.1
PPS Activation	2.3.2.1
Program Activation	2.3.2.1
Scheduling Limits for ACPs	Appendix C
CG-Resident Data Points	
Advanced Control Interface Data Point (ACIDP), defined	2.1.2
Calculated Results Data Point (CRDP), defined	2.1.2
Duties of	2.1.2
Preparation of	2.5.2
Role of	2.1.2

Index

Topic	Section Heading
Changing ACIDPS & CRDPS	5.4
Character-string messages	
Sending to an ACP	2.3
Checklist—See PG Checklist	
Checkpoint the CG	5.2.4
CIU, as Template value entry	4.2.1
CL Compiler	
to compile ACP	2.5.4
to compile Custom Data Segment	5.2.4
use of to define any Custom Data Segments	2.5.2
CL 'Initiate' Statement	2.3.2
CLAMP HI?, as Template value entry	4.2.1
CLAMP LOW?, as Template value entry	4.2.1
CLASS, Custom Data Segment Attribute	5.2.2
Cleanup Stage (PRGTRM)	2.3.4
CM Build and Configuration Menu	2.5.1, 5.3
Comment fields, defined	4.2
Cold Restart	6.2
Common Characteristics of User Interfaces	3.1.1
Commonly Encountered Problems	3.1.4
Compatibility of ACP with Its DDTs	3.1.3
Compile ACP	2.5.4
Compile Custom Data Segment	5.2.4
Computer Gateway — <i>See also</i> CG	1.1
Capacities Summary	Appendix C
Configuration of	2.5.1
Defined	1.2
Hardware components	1.2
Computer Operator Interfaces	2.3.3.2
Computing Module Target	5.3
Concepts and Mechanisms	Section 2
Configure CG	2.5.1
CONFWAIT (CG Parameter)	5.4 - Table 5-1, 5.4.1
CONSTANT, as Template value entry	4.2.1
<i>Control Language Reference Manual</i> , reference to	5.2
CRDP	
Changing	5.4
Defined	1.2, 2.1.2
Display of Parameters	5.4 - Table 5-2
Point Building	5.3
Viewing and Changing	5.4
Create new file system (PG implementation step)	6.1.2.2
Custom Data Segment	
Compilation Recommendation	5.2.4
Construction	5.2
Example	5.2.3
Heading	5.2.1
Limits	Appendix C
Parameters, listed	5.2.2
Cyclic exchange of data,	2.2

Index

Topic	Section Heading
Data Access	
Status Codes	Appendix A.1
Support in the 45000	2.4
DATA TABLE, as Template value entry	4.2.1
Data base, external address	2.1
Data base, internal address	2.1
Data Communicator Program, PGDCP	2.4
Data Definition Table (DDT)	
Defined	2.1.1
use of in Data Transfers	3.2
Data type	2.1.1
"Named"	2.1.1, 2.3, 4.1.1
Preparation	2.5.3
Role of	2.1.1
"Scheduled"	2.1.1, 2.2, 4.1.2
Table Builder	4.6
Templates	4.1.1, Table 4-1, 4.1.2
Listed	4.2
Types (of DDTs)	2.1.1
Data Entity Builder, use of	5.2, 5.3
Data Formats	3.1.2
Data link	
Communication with CG through Data Communicator	2.4
Connection to the Computer Gateway	1.2
TSDL Pinning Options	6.1.2.4
Data point	
Advanced Control Interface Data Point (ACIDP)	2.1.2
Calculated Results Data Point (CRDP)	2.1.2
Types	1.2, 2.1.2
Data Transfers	3.2
Get Data Interface	3.2.1
Store Data Interface	3.2.2
DDT — <i>See Data Definition Table</i>	
DDT Name Template	4.5.2
DDT Template Types, listed	4.2
DELAY, Execution state	5.3.1
Deletions Template	4.5.4
Dimensions of arrays	3.1.3
Display and Change of ACIDP Standard Parameters	5.4 - Table 5-1
Display of CRDP Parameters	5.4 - Table 5-2
DSAC02	4.6
Edit Checklist (PG implementation step)	
for PMC	6.1.2.2
for PMX	6.1.2.3
Enumeration data format	3.1.2
Enumeration Input Template	4.3.4, 3.2.1
Enumeration Output Template	4.4.4, 3.2.2
ENUMERATION as Template value entry	4.2.1
ENUMERATION SET ID as Template value entry	4.2.1
ENUMERATION SETS (PMX/PMC Checklist Entry)	6.1.2.1
Enumeration Set Definition Template	4.5.1

Index

Topic	Section Heading
Error — <i>See also Data Access Status Codes</i>	
Detection by Interface Calls	3.1.5
DSAC02	4.6
Messages - Run Time	Appendix B
Messages - RTMOS	3.1.5
EU, Custom Data Segment Attribute	5.2.2
Event Initiated Processing	2.3.2
EXECSTAT (CG Parameter)	3.4.2, 5.4 - Table 5-1, 5.4.1
External address (Data Base)	2.1
Fetch (a value) — <i>See value type (ASCII, integer, real, enumeration, etc.) ; see also</i>	
Input	
FILES IV	4.6
Error Message	3.1.5, 4.6
FREETIME IV	2.3, 2.3.3.2
Get ACP Status	2.3, 3.4 - 3.4.1.2
Get Data	3.2.1
Get Message	3.3.1
GETDTA, Subroutine — <i>See also Get Data</i>	2.3
GETMSG, Subroutine — <i>See also Get Message</i>	2.3
GETSTS, Subroutine — <i>See also Get Status</i>	2.3
Heading	
Custom Data Segment	5.2.1
HIGH LIMIT, as Template value entry	4.2.1
Implementation Steps	
ACP	2.5
PG on PMC	6.1.2.2
PG on PMX	6.1.2.3
Inhibit (ACP) Program	2.3.2.3
INH_STAT (CG Parameter)	
Described	5.4 - Table 5-1, 5.4.1
Initial setting note	2.3.2
Setting	6.1.1.1
INH_STAT target, to inhibit or permit program	2.3.2.3
Integer data format	3.1.2
Integer Input Template	4.3.2
Integer Input Template	4.4.2
Initialization Event types	5.4.1 (Note)
Input Table Templates	4.3 - 4.3.4
Input-ASCII (DDT Table Entry)	4.3.3
Input-Enumeration (DDT Table Entry)	4.3.4
Input-Integer (DDT Table Entry)	4.3.2
Input-Ordinal (DDT Table Entry)	4.3.5
Input-Real (DDT Table Entry)	4.3.1
Install an ACP Template	4.5.3
Installation	
of ACP	2.5 - 2.5.4
Modes	2.3.1
INSTALLED ACPs (PMX/PMC Checklist Entry)	6.1.2.1

Index

Topic	Section Heading
Interface	
ACP Termination	3.4.2
Computer Operator Interfaces	2.3.3.2
Error Detection by Interface Calls	3.1.5
Get ACP Status	3.4.1
Get Data	3.2.1
Get Message	3.3.1
Introduction to User Interface Routines	3.1
LCN Interface board	1.2
Operator Interfaces to ACP	2.3.3
Process Operator	2.3.3.1
Program Interfaces	Section 3
Send Message	3.3.2
Special interface subroutines	2.3, Section 3
Store Data	3.2.2
Subroutines Effective	2.3.1 - Table 2-2
System Interface ACIDP	6.1.1.1
Termination interface subroutine (PRGTRM)	2.3, 2.3.2.2
User Interface	Section 3
Common characteristics	3.1.1
Introduction to	3.1
Program Interfaces	Section 3
Routines	2.4, 3.1
Subroutines, listed	2.4
Internal address (Data Base)	2.1
K1,K2, as Template value entry	4.2.1
KEYWORD (CG Parameter)	5.4 - Tables 5-1/2, 5.4.1
LCN	
Communication with	2.3
Computer Gateway as LCN Node	1.2
Data access support in 45000	2.4
Interface board	1.2
Publications, listed	1.3
LF SUBST?	4.2.1
LF SUBST? as DDT table entry	4.3.1, 4.3.2, 4.3.4, 4.3.5
LIMIT CK?, as Template value entry	4.2.1
Limits, CG	Appendix C
Lists Template	4.5.5
Load to PMC 450 Target system (PG Implementation step)	6.1.2.2
Load to PMX Target system (PG Implementation step)	6.1.2.3
LOW LIMIT, as Template value entry	4.2.1
Memory Use Estimating (CG)	Appendix C
Main Directory (PMX/PMC Checklist Entry)	6.1.2.1
Message Size Limits	Appendix C
Message Transfers—See Text Message Transfers	
Messages, Run Time Error	Appendix B
MESSAGE_SIZE for Send Message	3.3.2.2
Modes, Restart	6.2
Modify PMX Programs (PG implementation step on PMX)	6.1.2.3

Index

Topic	Section Heading
NAME (CG Parameter)	5.4 - Tables 5-1/2, 5.4.1
Named DDTs	4.1.1
(PMX/PMC Checklist Entry)	6.1.2.1
Table Types and Data Types	4.1.1 - Table 4-1
<i>Network Form Instructions</i> , reference to	2.5.1
NEXT_RTM (CG Parameter)	5.4 - Table 5-1, 5.4.1
OPER_DMD (CG Parameter)	5.4 - Table 5-1, 5.4.1
Operator demand of Programs	2.3.2.1
Operator Interfaces to ACP	2.3.3
Options, Lists	4.5.5
Ordinal data format	3.1.2
Ordinal, Input Template	4.3.5
Ordinal, Output Template	4.4.5
ORDINAL as Template value entry	4.2.1
Output Table Templates	4.4
Output-ASCII (DDT Table Entry)	4.4.3
Output-Enumeration (DDT Table Entry)	4.4.4
Output-Integer (DDT Table Entry)	4.4.2
Output-Ordinal (DDT Table Entry)	4.4.5
Output-Real (DDT Table Entry)	4.4.1
Parameter	
45000	4.2.1
TDC3000 ^X	4.2.1
<i>Parameter Reference Dictionaries</i>	3.1.1
PARAMETER, as Template value	4.2.1
PGDCP (Data Communicator Program)	2.4, 6.1.1.1
PGDCP (Software Checklist Label)	6.1.2.1
Periodic and Cyclic Scheduling	2.3.2.1
PG Checklist on 45000	6.1.2.1
PG Implementation Steps	
on a PMC System	6.1.2.2
on a PMX System	6.1.2.3
PG Table Builder	2.4, Section 4
Named Data Definition Tables	4.1.1
Scheduled Data Definition Tables	4.1.2
Uses of	2.4
Use Steps	4.6
PGBLD — <i>See PG Table Builder</i>	
PGDCP	2.2, 6.1.1.1
Connection	2.2
PHASE, as Template value entry	4.2.1
PMC (Implementation of PG)	6.1.2.2
PMC/PMX Applications	1.2, Section 2 Preface
PMC/PMX Publications, Listed	1.3
PMX (Implementation of PG)	6.1.2.3
POINT NAME, as Template value entry	4.2.1
Point_Name.parameter (external address)	2.1
POINT RECORD, as Template value entry	4.2.1
PPS Activation	2.3.2.1
Preparing the 45000	6.1.2
Preparing the CG	6.1.1
Prepare CG-Resident Data Points	2.5.2
Prepare Data Definition Tables	2.5.3

Index

Topic	Section Heading
PRGTRM — <i>See also Program Termination</i>	
Subroutine	2.3
Problems, commonly encountered	3.1.4
Process Units, Assignment to CG	Appendix D
Process Operator Interfaces	2.3.3.1
Processor Gateway Role in TDC 3000 ^X Systems	1.1
Processor Gateway — <i>See also PG</i>	
Architecture	1.2
Defined	1.1, 1.2
Hardware and Software Structure	1.2 - Figure 1-1
Implementation Steps on PMC System	6.1.2.2
Implementation Steps on PMX System	6.1.2.3
Primary function	Section 2
Role in TDC 3000 ^X Systems	1.1
Software Checklist - 45000	6.1.2.1
Support functions	2.4
Program Inhibit	2.3.2.3
Program Termination— <i>See ACP Termination</i>	
Program abort alarm	2.3.2.2
Programmed Point Processing	2.3
PROGSTAT (CG Parameter)	5.4 - Table 5-1, 5.4.1, 6.1.1.1
PSP?, as Template value entry	4.2.1
PTDESC (CG Parameter)	5.4 - Tables 5-1/2, 5.4.1
RATE, as Template value entry	4.2.1
Real data format	3.1.2
Real, Input Template	4.3.1
Real, Output Template	4.4.1
References	1.3
Restart Modes	6.2
Return Status parameter	3.1.5
RTPERIOD (CG Parameter)	
Described	5.4 - Table 5-1, 5.4.1
Setting for cyclic and periodic ACP	5.3.1
Run Time Error Messages	Appendix B
RUN_INIT (CG Parameter)	5.4 - Table 5-1, 5.4.1, 6.1.1.1
SCHEDULE BASE, as Template value entry	4.2.1
Scheduled and Named Data Definition Tables	4.1, 4.1.1, 4.1.2
Scheduled DDTs	
Automatic cyclic exchange of data	2.2
Building	4.1
Described	4.1.2
Establishing scheduled point processing	2.2,
SCHEDULED DDTs (PMC/PMX Checklist Entry)	6.1.2.1
Types of	4.1.2
Template types	4.1.2, 4.2
Scheduled Point Processing	
Establishing	2.2, 4.1.2
Templates for	4.2
Scheduling, Operator Demand	2.3.2.1

Index

Topic	Section Heading
Send Message Interface	3.3.2
SNDMSG, Subroutine	2.3
Startup	6.1
Startup, System	Section 6
Status Codes	Appendix A
STATUS, as Template value entry	4.2.1
STIME (CG Parameter)	5.4 - Table 5-1, 5.4.1
Store Data Interface	3.2.2
Store (a value) — <i>See value type (ASCII, integer, real, enumeration, etc.); see also</i>	
Output	
STORE?, as Template value entry	4.2.1
STRDTA, Subroutine	2.3
<i>System Configuration Guide</i> , reference to	2.5.1
Support Functions	2.4
<i>System Control Functions Manual</i>	5.2
System Library File	5.2.4
System Interface ACIDP	6.1.1.1
System Startup	Section 6
Table Builder — <i>See PG Table Builder</i>	
TDC 3000 ^X	1.1, 1.2, 1.3, 2.1
Data access	2.1
Data base organization	2.1
Publications, references to	1.3
Template	
DDT listed by name	4.2
Define DDT Name	4.5.2
Definitions of Template Value Entries	4.2.1
Entries for Values	4.2.1
Enumeration Set Definition	4.5.1
Input Table Templates	
Input-ASCII	4.3.3
Input-Enumeration	4.3.4
Input-Integer	4.3.2
Input-Ordinal	4.3.5
Input-Real	4.3.1
Named DDT Templates	4.1.1, Table 4-1
Other Template Types	4.5
Define DDT Name Template	4.5.2
Deletions Template	4.5.4
Enumeration Set Definition Template	4.5.1
Install an ACP Template	4.5.3
Lists Template	4.5.5
Output Table Templates	4.4
Output-ASCII	4.4.3
Output-Enumeration	4.4.4
Output-Integer	4.4.2
Output-Ordinal	4.4.5
Output-Real	4.4.1
Scheduled DDTs	4.1.2
Types	4.3.2 - 4.5.5
Value Entries, Definitions	4.2.1

Index

Topic	Section Heading
Termination of ACP Execution	2.3, 2.3.2.2, 3.4.2 - 3.4.2.2
Termination Interface subroutine (PRGTRM)	2.3, 3.4.2.1
TEST VALUE, as Template value entry	4.2.1
Text Message Transfers	3.3
Get Message Interface	3.3.1
Send Message Interface	3.3.2
Timeout for Send Message	3.3.2.2
TSDL Data Link	1.2
Pinning Options	6.1.2.4
TYP SYS (PG Label)	6.1.2.1
UL (Update Library) Directive	5.2.4
Update Library Directive	5.2.4
UNIT (CG Parameter)	5.4 - Table 5-2, 5.4.1
Units, Process - Assignment to CG	Appendix D
Update Library Directive	5.2.4
USE TEST?, as Template value entry	4.2.1
User Interface Subroutines	2.4, Section 3
User Program Interfaces	Section 3
VALUE	
Custom Data Segment Attribute	5.2.4
as Template value entry,	4.2.1
Viewing and Changing ACIDPS & CRDPS	5.4
WAIT_TIME for Send Message	3.3.2.2
Warm Restart	6.2

READER COMMENTS

Honeywell IAC Automation College welcomes your comments and suggestions to improve future editions of this and other publications.

You can communicate your thoughts to us by fax, mail, or toll-free telephone call. We would like to acknowledge your comments; please include your complete name and address

BY FAX: Use this form; and fax to us at (602) 313-4108

BY TELEPHONE: In the U.S.A. use our toll-free number 1*800-822-7673 (available in the 48 contiguous states except Arizona; in Arizona dial 1-602-313-5558).

BY MAIL: Use this form; detach, fold, tape closed, and mail to us.

Title of Publication: **Processor Gateway User Manual** Issue Date: **8/95**

Publication Number: **PG11-510**

Writer: **B. Damours**

COMMENTS: _____

RECOMMENDATIONS: _____

NAME _____ DATE _____

TITLE _____

COMPANY _____

ADDRESS _____

CITY _____ STATE _____ ZIP _____

TELEPHONE _____ FAX _____

(If returning by mail, please tape closed; Postal regulations prohibit use of staples.)

Communications concerning technical publications should be directed to:

Automation College
Industrial Automation and Control
Honeywell Inc.
2820 West Kelton Lane
Phoenix, Arizona 85023-3028

FOLD

FOLD

From: _____




NO POSTAGE
NECESSARY
IF MAILED
IN THE USA

BUSINESS REPLY MAIL

FIRST CLASS PERMIT NO. 4332 PHOENIX, ARIZONA

POSTAGE WILL BE PAID BY

Honeywell
Industrial Automation and Control
2820 West Kelton Lane
Phoenix, Arizona 85023-3028



Cut Along Line

Attention: Manager, Quality

FOLD

FOLD

Additional Comments:

Honeywell

Industrial Automation and Control
Honeywell Inc.
16404 North Black Canyon Highway
Phoenix, Arizona 85023-3033

Helping You Control Your World